

6-440 KY 237 Multi-Use Path Project

BCFY22-26

Bid Opening: December 23, 2021

Questions & Answers #2

Q. It appears that there is not enough room to excavate for the Gravity Wall within the existing ROW without utilizing shoring unless there has been Temporary Easement acquired that is not shown on the plans. Please confirm that there is not additional Temporary Easement not shown for the construction of the Gravity Wall.

A. There is no temporary easement for the gravity wall. You may use shoring to stay within the Right of Way.

Q. Which forms are to be completed and submitted with our bid?

- Part IV- Certificates or
- Part VII- Bid Items

A. Please complete and return all the forms in Part IV and Part VII of the bid proposal.