

---

## **APPENDIX R**

# **WELL SITES EVALUATION**

---

# ***Technical Memorandum***

---



**To:** Mr. Mike Cho  
TRG Land, Inc.

**From:** Thomas Harder, P.G., C.HG.  
Thomas Harder & Co.

**Date:** 26-Aug-19

**Re:** Evaluation of Potential Well Sites for the Chadwick Ranch Estates

---

## **1 Introduction**

This technical memorandum (TM) summarizes the results of Thomas Harder & Company's (TH&Co's) evaluation and ranking of five potential well sites located in the San Gabriel Valley Groundwater Basin near Duarte, California in Los Angeles County. The siting study focused on potential sites that could accommodate a new well to be used as a water source for the proposed Chadwick Ranch Estates development in Bradbury, California (see Figure 1). The well siting analysis was focused on potential sites within Cal American Water's Duarte service area as the proposed development will be served by them.

### **1.1 Purpose and Scope**

The purpose of this investigation was to identify and rank five sites for their potential as production well sites. This TM presents the data, criteria, methodologies, and results for the site rankings and recommendations for future test drilling.

The scope of work consisted of:

- Obtaining and reviewing background data including groundwater elevation records, estimation of aquifer thickness, pumping test data, potential sources of groundwater contamination, aerial photographs of the Study Area, and parcel information.
- Identifying five potential sites for further investigation.
- Conducting site visits to each of the five sites.

Thomas Harder & Co.  
1260 N. Hancock St., Suite 109  
Anaheim, California 92807  
(714) 779-3875

- Ranking of the five potential well sites.
- Providing a recommendation for future drilling.
- Preparing this TM summarizing the findings.

## 1.2 Study Area

The Study Area was selected to be completely within Cal American Water's Duarte service area as shown on Figure 1. The Study Area is primarily south of Bradbury and west of the 605 Freeway. Land use in the area generally consists of urban residential areas, schools, commercial businesses and parks. Identification of potential well sites focused on vacant land, public properties or large undeveloped lots with available open space.

## 2 Hydrogeological Setting

The San Gabriel Valley Groundwater Basin (the Basin) is a structural basin filled with permeable alluvial deposits, underlain by relatively impermeable rock. It is located in eastern Los Angeles County and includes the water-bearing sediments underlying most of the San Gabriel Valley. The sediment that makes up this basin consists primarily of unconsolidated to semi-consolidated alluvium deposited by streams flowing out of the San Gabriel Mountains (see Figure 2). These alluvial sediments make up the primary aquifer system that supplies groundwater to most of the production wells in the area.

The bedrock underlying the alluvium consists of consolidated basement rocks of the San Gabriel Mountains<sup>1</sup>. The nonwater-bearing formations include igneous and metamorphic rocks. Although considered nonwater-bearing, wells drilled into them may intersect fractures containing water and can produce up to 15 gallons per minute (gpm)<sup>2</sup>.

A major northwest/southeast trending fault system is located at the base of the San Gabriel Mountains near the Chadwick Ranch Estates (see Figure 2). The primary fault in this system is the Sierra Madre Fault but it also includes the Duarte Fault, which is approximately 0.5-mile south and parallel to the Sierra Madre Fault. These faults act as groundwater flow barriers, impeding groundwater flow from the base of the mountains into the alluvial groundwater basin. Further, the low permeability nature of the sediments at and near the faults restricts well yields. Accordingly, it is advantageous to locate well sites away from the fault traces in order to maximize potential well yield.

---

<sup>1</sup> California Department of Water Resources (DWR). 2004. Bulletin 118. California's Groundwater. South Coast Hydrologic Region. *San Gabriel Valley Groundwater Basin*.

<sup>2</sup> Stetson Engineers, Inc, 2016. San Gabriel Valley Groundwater Basin Salt and Nutrient Management Plan. Prepared for the Main San Gabriel Basin Watermaster, Revised November 2016.



## 2.1 General Aquifer Characteristics

Alluvial sediments in the Study Area generally consist of sand, gravel, and boulders with some interbedded silt. Based on a review of the California Department of Water Resources (DWR) Driller's Log<sup>3</sup> for Buena Vista Well No. 2, which is located less than a mile from the potential sites, the subsurface sediments in this area consist primarily of sand, rock and gravel from ground surface to approximately 730 ft bgs (see Attachment A).

Where saturated in the subsurface, the permeable alluvium forms the aquifer that supplies water to wells. A pumping test of a well on the west side of the San Gabriel River at Huntington Drive was conducted at 3,500 gallons per minute (gpm) with 53 ft of drawdown after 28.5 hours (see Attachment A). The Buena Vista Well, located south of Interstate 210 and west of Interstate 605, yielded approximately 2,240 gpm during pumping tests in 2011. The Lemon Well, located north of Interstate 210 on the southwest border of Bradbury city limits, had a well yield of approximately 380 gpm in 2016, as determined from the Driller's Log (see Attachment A). Therefore, it is anticipated that wells south of the 210 freeway are anticipated to have greater potential well yield than wells north of the freeway.

## 2.2 Groundwater Occurrence and Flow

Groundwater level elevations have not changed from 2014 to 2019 in the Study Area. Based on a 2014 groundwater elevation contour map, groundwater generally flows in southwest direction<sup>2</sup>. Depth to groundwater beneath the potential sites is estimated to range from approximately 240 to 340 ft bgs, based on 2018-2019 simulated groundwater levels from the Main San Gabriel Basin Watermaster<sup>4</sup>.

## 2.3 Groundwater Quality

Groundwater quality within the Study Area is anticipated to be relatively good with respect to total dissolved solids (TDS) and nitrate concentrations. TDS concentrations in groundwater from area wells ranged from approximately 250 to 500 milligrams per liter (mg/L) in 2011-2012<sup>2</sup>, which is less than the secondary maximum contaminant level (MCL) for TDS of 500 mg/L. Nitrate concentrations in groundwater from wells ranges from approximately 2 to 25 mg/L, as reported in 2011-2012 (nitrate reported as nitrogen). Nitrate is likely associated with historical agriculture in the area and higher concentrations will be detected in the shallower aquifer system. Isolated zone testing will be an important aspect of the well drilling process to

<sup>3</sup> California Department of Water Resources (DWR) Well Completion Report Map Application. <https://dwr.maps.arcgis.com/apps/webappviewer/index.html?id=181078580a214c0986e2da28f8623b37>. Accessed 2018-2019.

<sup>4</sup> Stetson Engineers, Inc. Prepared for Main San Gabriel Basin Watermaster, Simulated 2018-19 Basin Groundwater Contours, Figure 18. [https://docs.wixstatic.com/ugd/af1ff8\\_5c0ffdec3be548f6acef9e6dda92428.pdf](https://docs.wixstatic.com/ugd/af1ff8_5c0ffdec3be548f6acef9e6dda92428.pdf)



ensure that the well is designed with a perforation interval below the shallow zones of high nitrate.

In addition to general water quality issues, there are a number of previously identified sources of groundwater contamination in the vicinity of the Study Area (see Figure 3). Possible point-sources of contamination were identified using the State Water Resources Control Board (SWRCB) Geotracker<sup>5</sup> website. Various potential contaminating activities in the Study Area include, but are not limited to, permitted underground storage tanks (USTs), land disposal sites, and closed Leaking Underground Storage Tank (LUST) cleanup sites, as shown on Figure 3. The constituents of concern at these sites are primarily associated with gasoline and oil.

Volatile organic compounds (VOCs) have also been detected in groundwater in the Study Area. There are multiple Superfund National Priority List (NPL) Sites in the San Gabriel Valley Groundwater Basin<sup>2</sup>. NPL Sites are hazardous waste sites eligible for long term remedial action (cleanup) financed by the federal Superfund program. The NPL site closest to the Study Area is located in the city of El Monte in the western portion of the Study Area (see Figure 3). The VOCs associated with this site include Trichloroethylene (TCE), Perchloroethylene (PCE) and Carbon Tetrachloride<sup>6</sup>. For wells sites in the western portion of the Study Area, isolated aquifer zone testing that includes testing for VOCs will be critical to avoid designing the well with perforations in aquifers with high VOC concentrations.

---

<sup>5</sup> State Water Resources Control Board (SWRCB), <http://geotracker.waterboards.ca.gov/>. Accessed 2019.

<sup>6</sup> United States Environmental Protection Agency (EPA). <https://www.epa.gov/superfund/search-superfund-sites-where-you-live#map>. Accessed 2019.



### 3 Evaluation of Potential Well Sites

Based on a review of online aerial imagery, vacant parcels, and parcel ownership, TH&Co identified five preliminary site locations within the Study Area for further evaluation as potential well sites (see Figures 1 and 4). Vacant parcels were identified using Los Angeles County's parcel database (dated 2016). TH&Co gave the proposed respective Assessor's Parcel Number (APN) to TRG for review on the First American title database to determine parcel owner and property value. TH&Co visited each of the five preliminary sites on 25-Jun-19 to evaluate the following:

- Rig access from the main roads
- Levelness of the property
- Presence of overhead utilities
- Signs of underground utilities
- Site dimensions
- Nearby potential contaminant sources (e.g. sewer manholes)

The following items were noted during the site visit but were not used in the ranking and evaluation of the potential sites:

- Locations for discharge water generated during drilling
- Potential sources of water for drilling (i.e. fire hydrants)
- Need for noise control attenuation
- Amount of traffic surrounding the site

Further work to identify subsurface utilities will be necessary prior to finalizing the exact drilling location on each of the sites.

The following summarizes the evaluation of the five sites based on the site visit.

#### 3.1 Site 1 – New Hope Church's Undeveloped Lot

Site 1 is a vacant, undeveloped parcel located at the intersection of Mountain Avenue and Euclid Avenue (see Figure 5). The parcel is privately-owned by New Hope Church of God in Christ in Duarte. The site contains adequate space for drilling rig and equipment. There are some trees on the site that might need to be removed.





### **Evaluation Criteria – Site 1**

Property Access/Ownership	Private Property owned by New Hope Church
Assessor Parcel Number (APN)	8521-008-047
Proximity to Existing Pipeline	Unknown
Proximity to Existing Well	Approximately 3,700 ft
Approximate Property Dimensions (Length x Width)	200 ft x 200 ft
Rig Access	Driveway from Euclid Avenue. Accessible level land. Minor site preparation might be required to remove trees (if necessary).
Observed Utilities	No overhead power lines trending across the site.
Potential Contaminant Sources	No sewer manholes observed on site.
Distance from Existing Active or Closed Clean-Up Sites	Approximately 0.3 miles away
Noise Control	Noise control (i.e. sound walls) will likely be necessary due to the surrounding residences.






Construction Water	Fire hydrant located across the street from the site on Mountain Avenue.
Traffic	Low – High (especially on weekends when church is in session)

### 3.2 Site 2 – Westminster Garden

Site 2 consists of a mostly vacant, undeveloped parcel owned by Westminster Gardens. Westminster Gardens is a senior living retirement community. The site is located within a residential neighborhood near the intersection of Santo Domingo Avenue and Huntington Drive (see Figure 6). The site contains adequate space for drilling rig and equipment. There are boulders and trees on site as well as unlevel land, so site maintenance will likely be necessary. A review of aerial imagery suggests this site is periodically used as a parking lot for the senior community. At the time of the site visit, there were no cars and gates were closed and locked.



#### Evaluation Criteria

Property Access/Ownership	Privately owned by Westminster Gardens
Assessor Parcel Number (APN)	8529-014-029
Proximity to Existing Pipeline	Unknown
Proximity to Existing Well	Approximately 1,380 ft
Approximate Property Dimensions (Length x Width)	230 ft x 270 ft





Rig Access	Driveway off of Santo Domingo Avenue through gate; Minor site maintenance may be necessary.
Observed Utilities	No powerlines extending across the site.
Potential Contaminant Sources	Sewer manhole located on Santo Domingo Avenue.
Distance from Existing Active or Closed Clean-Up Sites	Approximately 0.25 miles away
Noise Control	Noise control (i.e. sound walls) will likely be necessary due to the surrounding residences.
Construction Water	Fire hydrant located across the street from the site on Santo Domingo Avenue. Storm drain located across the street on Santo Domingo Avenue.
Traffic	Low traffic on side street, high traffic on Huntington Drive.

### 3.3 Site 3 – Undeveloped Lot Off of Mountain Avenue and East Duarte Road

Site 3 is a vacant, undeveloped parcel located at the intersection of Mountain Avenue and East Duarte Road (see Figure 7). The parcel is owned by the City of Duarte. The site contains adequate space for drilling rig and equipment. Some minor site preparation may be necessary to grade the site. The site dips steeply downwards from the surrounding sidewalk on the north and west portions of the site.



### **Evaluation Criteria**

Property Access/Ownership	Property owned by the City of Duarte
Assessor Parcel Number (APN)	8531-017-903
Proximity to Existing Pipeline	Unknown
Proximity to Existing Well	Approximately 3,200 ft
Approximate Property Dimensions (Length x Width)	110 ft x 140 ft
Rig Access	There is no driveway into the lot but would be best to enter over the curb on Mountain Avenue. Minor site preparation may be necessary to grade the steep sides of the site.
Observed Utilities	Electrical vaults located in the sidewalk along East Duarte Road. No overhead power lines trending across the site.
Potential Contaminant Sources	Sewer manholes were not observed.
Distance from Existing Active or Closed Clean-Up Sites	Approximately 0.1 miles away
Noise Control	Noise control (i.e. sound walls) will likely be necessary due to the surrounding residences.
Construction Water	Hydrant located across the street on Mountain Avenue.
Traffic	Moderate - High (busy intersection)

### **3.4 Site 4 – Dura Properties’ Parking Lot**

Site 4 is a parking lot adjacent to the train tracks at the intersection of Buena Vista Street and East Duarte Road (see Figure 8). It is privately-owned by Dura Properties, LLC. The site



contains adequate space for drilling rig and equipment. Minor site maintenance might be necessary to remove trees and to redirect a power line trending through the site.



### **Evaluation Criteria**

Property Access/Ownership	Privately owned by Dura Properties, LLC
Assessor Parcel Number (APN)	8528-005-053
Proximity to Existing Pipeline	Unknown
Proximity to Existing Well	Approximately 1,450 ft
Property Dimensions (Length x Width)	220 ft x 80 ft
Rig Access	Driveway into site off of Buena Vista Street. Minor site preparation might be required to remove trees and re-route pipeline (if necessary).
Observed Utilities	Overhead powerline ends on site. Utility building for train control on southern portion of the site.
Potential Contaminant Sources	Sewer manhole located on Buena Vista Street (at least 100 ft away)
Distance from Existing Active or Closed Clean-Up Sites	Approximately 0.05 miles away
Noise Control	Noise control (i.e. sound walls) will likely be necessary due to the






	surrounding residences.
Construction Water	Fire hydrant located at intersection of Buena Vista Street and Three Ranch Road. Storm drain located on Buena Vista Street sidewalk.
Traffic	Moderate - High (busy intersection)

### 3.5 Site 5 - Undeveloped Lot off Huntington Drive

Site 5 is a vacant, undeveloped parcel located off of Huntington Drive and Pops Road (see Figure 9). The parcel is owned by the City of Duarte. The site contains adequate space for drilling rig and equipment. The southern portion of the site has a berm and the western portion of the site dips down. Currently the site contains plants and trees with irrigation lines and hoses along the perimeter, so minor site preparation may be necessary to grade the site and remove any plants as deemed necessary.



#### Evaluation Criteria

Property Access/Ownership	Property owned by the City of Duarte
Assessor Parcel Number (APN)	8530-023-917
Proximity to Existing Pipeline	Unknown
Proximity to Existing Well	Approximately 2,250 ft
Property Dimensions (Length x Width)	140 ft x 135 ft

Rig Access	Access over the curb from Huntington Drive. Minor site preparation may be necessary.
Observed Utilities	No overhead powerlines trend along the site.
Potential Contaminant Sources	Two sewer manholes observed on Pops Road.
Distance from Existing Active or Closed Clean-Up Sites	Approximately 0.08 miles away
Noise Control	Noise control (i.e. sound walls) will likely be necessary due to the surrounding residences.
Construction Water	Fire hydrant located on site off of Huntington Drive.
Traffic	Moderate – High traffic along Huntington Drive



## 4 Methodology of Site Ranking

Each of the potential well sites evaluated for this study was ranked according to the following evaluation categories:

- Ease of property access
- Proximity to existing wells
- Potential well yield
- Proximity to potential contaminant sources
- Adequate space to drill the well
- Drilling rig access

Each evaluation category was assigned a subjective weighting factor (between 0.1 and 0.3) based on its relative importance to selecting a site. Evaluation categories were further assigned raw scores based on evaluation criteria that would make the site more or less favorable as a well site.

The ranking of the sites is a function of the weighting factor and the assigned raw score for each evaluation category (see Table 1). The product of the weighting factor and raw score results in a weighted score for each category (see Table 2). The sum of the weighted scores results in a final score that is ranked with the other sites. The site with the highest weighted score is ranked first, the next highest score is ranked second and so on.

## 5 Results of Site Ranking and Recommendations

Based on the results of our evaluation, the five potential well sites have been ranked in the following order (in order of most favorable to least favorable):

1. Site 3 (Undeveloped Lot off Mountain Avenue and East Duarte Road)
2. Site 1 (New Hope Church's Undeveloped Lot)
3. Site 5 (Undeveloped Lot off Huntington Drive)
4. Site 4 (Dura Properties' Parking Lot)
5. Site 2 (Westminster Garden)


Of the sites reviewed, all of them score moderately to very high in most of the evaluation criteria categories. Based on the evaluation criteria categories and the weighting factors, Site 3 is the highest ranked based on ease of property access, proximity to existing wells, potential well yield, proximity to potential contaminant sources, adequate space for drilling equipment, and drilling rig access.






# Figures







Evaluation of Potential Well Sites  
for the Chadwick Ranch Estates




Map Features

- Geologic Unit**
- Artificial Fill
  - Alluvial Deposits
  - Old Alluvial Deposits
  - Fine- and Coarse-grained Tertiary age sediments
  - Coarse-grained formations of Pleistocene age sediments
  - Tertiary age formations of volcanic origin
  - Crystalline Bedrock
  - Landslide Deposits
  - Undifferentiated Surficial Deposits
  - San Gabriel Valley Groundwater Basin
  - Potential Well Site
  - Chadwick Ranch Estates
  - Fault
  - San Gabriel River
  - Freeway
  - Existing Well

Note: Geology modified from California Geological Survey, Special Report 217 (Revised, 2012) and USGS Open-File Report 2005-1305

Well Locations from CASGEM and DWR Driller's Logs








TRG Land

## Evaluation of Potential Well Sites for the Chadwick Ranch Estates

26-Aug-19



**Thomas Harder & Co.**  
Groundwater Consulting



NAD 83 UTM Zone 11

Note: Well Locations from CASGEM and DWR Driller's Logs.  
Parcels from Los Angeles County Parcel Assessor, 2016.

**Potential Well Sites**  
**Figure 4**















TRG Land

**Evaluation of Potential Well Sites  
for the Chadwick Ranch Estates**

26-Aug-19



**Thomas Harder & Co.**  
Groundwater Consulting



NAD 83 UTM Zone 11

Note: Parcel from Los Angeles County Parcel Assessor, 2016.

**Site 5  
Figure 9**

# Tables



**Analysis of Potential Well Sites  
Well Sites Evaluation Criteria**

Evaluation Category	Weighting Factor <sup>1</sup>	Raw Score Criteria	Raw Score
<b><i>Ease of Property Access</i></b>	0.3	Public or Local Agency	10
		Private Property/Purchase Required	5
<b><i>Proximity to Existing Wells</i></b>	0.2	> 2,500 ft	10
		1,500 - 2,500 ft	5
		< 1,500 ft	1
<b><i>Potential Well Yield</i></b>	0.15	Located South of the 210	10
		Located North of the 210	5
<b><i>Proximity to Potential Contamination Sources</i></b>	0.15	> 0.5 mile from Active or Closed Clean-up Site and No Sewer Manholes within 100 ft of Site	10
		0.25 - 0.5 mile from Active or Closed Clean-up Site and No Sewer Manholes within 100 ft of Site	5
		< 0.25 mile from Active or Closed Clean-up Site and/or <100 ft from Sewer Manhole	3
<b><i>Adequate Space to Drill the Well</i></b>	0.1	≥ 100 ft by 100 ft	10
		< 100 ft by 100 ft	5



Analysis of Potential Well Sites  
Well Sites Evaluation Criteria

Evaluation Category	Weighting Factor <sup>1</sup>	Raw Score Criteria	Raw Score
<b>Drilling Rig Access</b>	0.1	Accessible Level Land	10
		Minor Site Preparation Required	5
		Major Site Preparation Required	1
Total		1	

**Notes:**

<sup>1</sup>The weighting factor is a subjective term that indicates relative importance for evaluating potentially successful well sites. Higher values are assigned to categories with higher relative importance.

Analysis of Potential Well Sites  
Well Sites Ranking Results

Evaluation Category	Weighting Factor	Weighted Score									
		Site 1		Site 2		Site 3		Site 4		Site 5	
		a	b	a	b	a	b	a	b	a	b
<i>Ease of Property Access</i>	0.3	5	1.5	5	1.5	10	3	5	1.5	10	3
<i>Proximity to Existing Wells</i>	0.2	10	2	1	0.2	10	2	1	0.2	5	1
<i>Potential Well Yield</i>	0.15	10	1.5	5	0.8	10	1.5	10	1.5	5	0.8
<i>Proximity to Potential Contamination Sources</i>	0.15	5	0.8	3	0.5	3	0.5	3	0.5	3	0.5
<i>Adequate Space to Drill the Well</i>	0.1	10	1	10	1	10	1	5	0.5	10	1
<i>Drilling Rig Access</i>	0.1	10	1	5	0.5	5	0.5	5	0.5	5	0.5
Totals	1	50	7.8	29	4.4	48	8.5	29	4.7	38	6.7
Rank		2		5		1		4		3	

Notes:

a Raw score between 1-10. This is a subjective value based on the presence or absence of favorable site criteria.

b Weighted score - the product of the weighting factor and raw score.

# Attachment A

## **DWR Well Driller's Logs**



JAN 25 1968

ORIGINAL

File with DWR

## WATER WELL DRILLERS REPORT

(Sections 7079, 7080, 7081, 7082, Water Code)

THE RESOURCES AGENCY OF CALIFORNIA  
DEPARTMENT OF WATER RESOURCES


N.I. 15415

Do Not Fill In

No 35116

State Well No. DIN/10W-29R2

Other Well No.

<p>(1) LOCATION OF WELL:  County <b>Los Angeles</b>      Owner's number, if any _____  Township, Range, and Section <b>West side of the San</b>  Distance from cities, roads, railroads, etc. <b>Gabriel River and</b>  <b>Huntington Drive, Duarte, Calif</b></p> <p>(2) TYPE OF WORK (check):  New Well <input checked="" type="checkbox"/>    Deepening <input type="checkbox"/>    Reconditioning <input type="checkbox"/>    Destroying <input type="checkbox"/>  If destruction, describe material and procedure in Item 11.</p> <p>(3) PROPOSED USE (check):  Domestic <input type="checkbox"/>    Industrial <input type="checkbox"/>    Municipal <input type="checkbox"/>  Irrigation <input type="checkbox"/>    Test Well <input type="checkbox"/>    Other <input checked="" type="checkbox"/></p> <p>(4) EQUIPMENT:  Rotary <input type="checkbox"/>  Cable <input checked="" type="checkbox"/>  Other <input type="checkbox"/></p> <p>(5) CASING INSTALLED:  STEEL: _____    OTHER: _____  SINGLE <input type="checkbox"/>    DOUBLE <input checked="" type="checkbox"/></p> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>From ft.</th> <th>To ft.</th> <th>Diam.</th> <th>Gage or Wall</th> <th>Diameter of Bore</th> <th>From ft.</th> <th>To ft.</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>600</td> <td>20</td> <td>No. 8 gauge double well casing</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p>Size of shoe or well ring: <b>20x14x1-1/4"</b>    Size of gravel: _____  Describe joint _____</p> <p>(6) PERFORATIONS OR SCREEN:  Type of perforation or name of screen _____</p> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>From ft.</th> <th>To ft.</th> <th>Perf. per row</th> <th>Rows per ft.</th> <th>Size in. x in.</th> </tr> </thead> <tbody> <tr> <td>350</td> <td>580</td> <td>9 holes</td> <td>per 5</td> <td>inches</td> </tr> </tbody> </table> <p>(7) CONSTRUCTION:  Was a surface sanitary seal provided? Yes <input type="checkbox"/> No <input type="checkbox"/> To what depth _____ ft.  Were any strata sealed against pollution? Yes <input type="checkbox"/> No <input type="checkbox"/> If yes, note depth of strata _____  From _____ ft. to _____ ft.  From _____ ft. to _____ ft.  Method of sealing _____</p> <p>(8) WATER LEVELS:  Depth at which water was first found, if known <b>270</b> ft.  Standing level before perforating, if known <b>265</b> ft.  Standing level after perforating and developing <b>265</b> ft.</p> <p>(9) WELL TESTS:  Was pump test made? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> If yes, by whom? <b>Roscoe Moss</b>  Yield: <b>3500</b> gal./min. with <b>53</b> ft. drawdown after <b>28.5</b> hrs.  Temperature of water _____    Was a chemical analysis made? Yes <input type="checkbox"/> No <input type="checkbox"/>  Was electric log made of well? Yes <input type="checkbox"/> No <input type="checkbox"/> If yes, attach copy _____</p>	From ft.	To ft.	Diam.	Gage or Wall	Diameter of Bore	From ft.	To ft.	0	600	20	No. 8 gauge double well casing				From ft.	To ft.	Perf. per row	Rows per ft.	Size in. x in.	350	580	9 holes	per 5	inches	<p>(11) WELL LOG:</p> <p>Total depth <b>600</b> ft.    Depth of completed well _____ ft.  Formation: Describe by color, character, size of material, and structure _____  ft. to _____ ft.</p> <p><b>0 to 190' Gravel, sand and boulders</b>  <b>190 to 255' Sand and gravel</b>  <b>255 to 275' Gravel, sand and some boulders</b>  <b>275 to 300' Loose sand and gravel</b>  <b>300 to 320' Sand and gravel and small gravel</b>  <b>320 to 405' Sand and gravel, boulders to 12"</b>  <b>405 to 412' Cemented sand and gravel 2"</b>  <b>412 to 486' Sand, gravel and boulders to 10"</b>  <b>486 to 600' Sand, gravel and boulders to 6"</b></p> <p style="text-align: center; font-weight: bold; font-size: 1.2em;">CONFIDENTIAL - NOT FOR PUBLIC RELEASE</p> <p>Work started <b>10-2-67</b>, Completed <b>12-30-67</b></p> <p>WELL DRILLER'S STATEMENT:  This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.</p> <p>NAME <b>Roscoe Moss Company</b>  (Person, firm, or corporation) (Typed or printed)</p> <p>Address <b>4360 Worth Street</b>  <b>Los Angeles, California.</b></p> <p>[SIGNED]  (Well Driller)    Secretary</p> <p>License No. <b>624 C-57</b>    Dated <b>Jan 24, 1968</b>, 19____</p>
From ft.	To ft.	Diam.	Gage or Wall	Diameter of Bore	From ft.	To ft.																			
0	600	20	No. 8 gauge double well casing																						
From ft.	To ft.	Perf. per row	Rows per ft.	Size in. x in.																					
350	580	9 holes	per 5	inches																					

SKETCH LOCATION OF WELL ON REVERSE SIDE

Land situated in the County of Los Angeles, State of California, described as follows:

That portion of Section 29, Township 1 North, Range 10 West, in the Rancho Azusa de Duarte, in the City of Irwindale, in the County of Los Angeles, State of California, as per map recorded in Book 6 Page 80 to 82 of Miscellaneous Records, in the Office of the County Recorder of said County, described as follows:

Beginning at the intersection of the Southwesterly line of Tract No. 13436, as per map recorded in Book 294, Page 20 of Maps, Records of said County, with the Southwesterly prolongation of the Northwestern line of Lot 56 of said Tract No. 13436, thence along said prolongation South  $25^{\circ} 24' 22''$  West 441.44 Feet, thence North  $45^{\circ} 07' 07''$  East to the Southwesterly line of said Tract No. 13436 and the true point of beginning; thence Northwesterly along said Southwesterly line, a distance of 55.00 feet, thence South  $25^{\circ} 24' 22''$  West along a line parallel with the Northwestern line of said Lot 56 and its Southwesterly prolongation to the intersection of that certain line above described as North  $45^{\circ} 07' 07''$  East, thence along last mentioned line, North  $45^{\circ} 07' 07''$  East to the true point of beginning.

CALIFORNIA AMERICAN WATER CO.  
SAN GABRIEL VALLEY DIVISION  
DUARTE DISTRICT

CROWNHAVEN  
WELL PLANT  
DESCRIPTION

35116

IN/10W-2922

76W348 106 REV. Cdb 7-60

SHEET 1

LOS ANGELES COUNTY  
FLOOD CONTROL DISTRICT  
Water Conservation Division  
WELL DATA

## Location and Description:

25. 322' SW of S.W. curb of Huntington Drive;  
26. 210' E. of E. curb of Crownpoint Drive  
89' N. of 14' W. of power transmission line tower  
Use: None-4-29-68 #105-3-113' SW of power-  
pole #1041294E

Elev. of average grd. at well: 575 ±' U. S. G. S. Datum

Elev. of grd. adjacent to well: U. S. G. S. Datum

## Water surface reference points:

(a) From 4-29-68 To Elev. 576.3 How det. Topo.  
Description: Top of 20" casing, 1.3' above grd.

(b) From 5-14-68 To Elev. 576.7 How det. Topo.  
Description: Top of 2 1/2" mess. pipe, 1.7' above grd.

(c) From To Elev. How det.  
Description:

(d) From To Elev. How det.  
Description:

Type of well: Cable Tool Size 20"-600'

Original depth: 600' Soundings:

Pumping equipment: None-4-29-68

Power used:

Capacity: 3500 GPM Drawdown: 53'; W.L. @ 267 prior to test

Date drilled: 12-30-67 By Roscoe Moss Co.

Artesian characteristics:

Quality of water:

Remarks: Well field checked-4-29-68

(over)

Well Numbers

Owner

D.W.R.  
IN/10W-2922 Loc.

D.W.R.

F.C. 4256



LOG OF WELL NO. 4256

[illegible]Perforations 350' - 580'

Placed cement plug in bottom of well.

Struck water at 270

Water level before perf. 265' after perf. 268'

Remarks. Above log obtained from owner

Confidential Well Log & other data in Confidential Well Log Files  
(over)

(over)

4256



STATE OF CALIFORNIA  
**WELL COMPLETION REPORT**

Refer to Instruction Pamphlet

MVR 7/21/2011

DWR USE ONLY - DO NOT FILL IN

01N10W31M002S											
STATE WELL NO./STATION NO.											
LATITUDE						LONGITUDE					
APN/TRS/OTHER											

Page 1 of 2Owner's Well No. Buena Vista Well #2No. e0131337Date Work Began November 2010 Ended April 12 2011Local Permit Agency Los Angeles County Dept Env HealthPermit No. 890962 Permit Date 10/26/10**GEOLOGIC LOG**

WELL OWNER

ORIENTATION (X) ☒ VERTICAL ☐ HORIZONTAL ☐ ANGLE ☐ (SPECIFY)

DRILLING METHOD

Reverse Rotary

FLUID

**DESCRIPTION**

DEPTH FROM SURFACE

FL to Ft.


Describe material, grain size, color, etc.

40	360	Sand & Rock
360	370	Sand, some rock
370	440	Sand & Rock
440	450	Little Sand & Rock
450	480	Sand & Rock
480	490	Clay, sand, & rock
490	500	Sand & Rock
500	510	Sand & Little Rock
510	680	Sand & Rock
680	700	Sand & Gravel
700	734	Sand, gravel, some cobbles

Address 2006 Buena Vista StCity Duarte CaCounty Los Angeles STATE Ca ZIPAPN Book 8533 Page 008 Parcel 026Township 1N Range 10W Section 31MLatitude 34 7 41.7 NORTH Longitude 117 58 34 WEST

DEG. MIN. SEC.

DEG. MIN. SEC.

**LOCATION SKETCH****ACTIVITY (X)**☒ NEW WELL  
☐ MODIFICATION/REPAIR☐ Deepen  
☐ Other (Specify)☐ DESTROY (Describe Procedures and Materials Under "GEOLOGIC LOG")**PLANNED USES (X)**WATER SUPPLY ☒  
☐ Domestic ☒ Public  
☐ Irrigation ☐ IndustrialMONITORING ☐TEST WELL ☐CATHODIC PROTECTION ☐HEAT EXCHANGE ☐DIRECT PUSH ☐INJECTION ☐VAPOR EXTRACTION ☐SPARGING ☐

REMEDICATION -

OTHER (SPECIFY) ☐

Illustrate or Describe Distance Of Well from Roads Buildings, Fences, Rivers etc and attach map. Use additional paper if necessary. PLEASE BE ACCURATE &amp; COMPLETE.

**WATER LEVEL & YIELD OF COMPLETED WELL**DEPTH TO FIRST WATER Unknown (Ft.) BELOW SURFACEDEPTH OF STATIC WATER LEVEL 196.05 (Ft.) & DATE MEASURED 4/7/2011-4/13/2011ESTIMATED YIELD 2,240 (GPM) & TEST TYPE Step, develop, constantTEST LENGTH 53.5 (Hrs.) TOTAL DRAWDOWN 8.35 (Ft.)

\* May not be representative of a well's long-term yield.

TOTAL DEPTH OF BORING 734 (Feet)TOTAL DEPTH OF COMPLETED WELL 720 (Feet)

DEPTH FROM SURFACE			BORE-HOLE DIA. (inches)	CASING (S)						DEPTH FROM SURFACE	ANNULAR MATERIAL							
				TYPE (-')				MATERIAL / GRADE	OUTSIDE DIAMETER (inches)		GAUGE OR WALL THICKNESS	SLOT SIZE IF ANY (inches)	TYPE					
Ft.	to	Ft.	BLANK	SCREEN	CON- DUCTOR	FILL PIPE									Ft.	to	Ft.	CE- MENT (X)
0	:	40	44			X		LCS	36	.375		0	:	264	X			10.3 sack sand slurry
0	:	300	32	X				LCS	18	.312		264	:	269				Transition Seal
300	:	340	32		X			LCS-Ful-Flo	18	.312	.070 slotted	269	:	734			X	1/4x16 Tacna
340	:	360	32	X				LCS	18	.312			:					
360	:	472	32		X			LCS-Ful-Flo	18	.312	.070 slotted		:					
472	:	490	32	X				LCS	18	.312			:					

**ATTACHMENTS (X)**

- ☒ Geologic Log  
☒ Well Construction Diagram  
☒ Geophysical Log(s)  
☐ Soil/Water Chemical Analyses  
☒ Other Test Pump Data; Well Survey

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

**CERTIFICATION STATEMENT**

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.

Layne Christensen Company

NAME (PERSON, FIRM, OR CORPORATION) (TYPED OR PRINTED)

11001 Etiwanda Ave

ADDRESS

FontanaCa92337

Signed

WELL DRILLER/AUTHORIZED REPRESENTATIVE

DATE SIGNED 6/1/2011STATE 510011

C-57 LICENSE NUMBER

STATE OF CALIFORNIA  
**WELL COMPLETION REPORT**

Refer to Instruction Pamphlet

Page 2 of 2Owner's Well No. Buena Vista Well #2No. e0131337Date Work Began November 2010 Ended April 12 2011Local Permit Agency Los Angeles County Dept Env HealthPermit No. 890962 Permit Date 10/26/10

DWR USE ONLY - DO NOT FILL IN									
STATE WELL NO./STATION NO.									
LATITUDE					LONGITUDE				
APN/TRS/OTHER									

**GEOLOGIC LOG**

ORIENTATION (X)		X VERTICAL _____ HORIZONTAL _____ ANGLE _____ (SPECIFY)	
DEPTH FROM SURFACE		DRILLING METHOD _____ Reverse Rotary _____ FLUID _____	
FL to Ft.		DESCRIPTION	
		Describe material, grain size, color, etc.	
40	360	Sand & Rock	
360	370	Sand, some rock	
370	440	Sand & Rock	
440	450	Little Sand & Rock	
450	480	Sand & Rock	
480	490	Clay, sand, & rock	
490	500	Sand & Rock	
500	510	Sand & Little Rock	
510	680	Sand & Rock	
680	700	Sand & Gravel	
700	734	Sand, gravel, some cobbles	

**WELL OWNER**

WELL LOCATION  
Address 2006 Buena Vista St  
City Duarte State Ca ZIP  
County Los Angeles  
APN Book 8533 Page 008 Parcel 026  
Township 1N Range 10W Section 31  
Latitude 34 7 41.7 NORTH Longitude 117 58 34 WEST  
DEG. MIN. SEC. DEG. MIN. SEC.

**LOCATION SKETCH**

Illustrate or Describe Distance of Well from Roads Buildings, Fences, Rivers etc and attach map. Use additional paper if necessary. PLEASE BE ACCURATE & COMPLETE.

ACTIVITY (X)  
☒ NEW WELL  
☐ MODIFICATION/REPAIR  
\_\_\_\_ Deepen  
\_\_\_\_ Other (Specify)

DESTROY (Describe Procedures and Materials Under "GEOLOGIC LOG")

**PLANNED USES (X)**

WATER SUPPLY  
☒ Domestic ☒ Public  
☐ Irrigation ☐ Industrial

MONITORING \_\_\_\_\_  
TEST WELL \_\_\_\_\_  
CATHODIC PROTECTION \_\_\_\_\_  
HEAT EXCHANGE \_\_\_\_\_  
DIRECT PUSH \_\_\_\_\_  
INJECTION \_\_\_\_\_  
VAPOR EXTRACTION \_\_\_\_\_  
SPARGING \_\_\_\_\_  
REMEDICATION -  
OTHER (SPECIFY) \_\_\_\_\_

**WATER LEVEL & YIELD OF COMPLETED WELL**

DEPTH TO FIRST WATER Unknown (Ft.) BELOW SURFACE

DEPTH OF STATIC WATER LEVEL 196.05 (Ft.) & DATE MEASURED 4/7/2011-4/13/2011

ESTIMATED YIELD 2,240 (GPM) & TEST TYPE Step, develop, constant

TEST LENGTH 53.5 (Hrs.) TOTAL DRAWDOWN 8.35 (Ft.)

\* May not be representative of a well's long-term yield.

TOTAL DEPTH OF BORING 734 (Feet)  
TOTAL DEPTH OF COMPLETED WELL 720 (Feet)

DEPTH FROM SURFACE			BORE-HOLE DIA. (inches)	CASING (S)						DEPTH FROM SURFACE	ANNULAR MATERIAL							
				TYPE (-)				MATERIAL / GRADE	OUTSIDE DIAMETER (inches)		GAUGE OR WALL THICKNESS	SLOT SIZE IF ANY (Inches)	TYPE					
Ft.	to	Ft.	BLANK	SCREEN	CON- DUCTOR	FILL PIPE									Ft.	to	Ft.	CE- MENT (X)
490	:	700	32	X				LCS-Ful-Flo	18	.312	.070 slotted	0	:	264	X			10.3 sack cement
700	:	720	32	X				LCS-S.E. Head	18	.312		264	:	269				Transition Seal
	:											269	:	734			X	1/4x16 Tacna
	:												:					
	:												:					
	:												:					
	:												:					

**ATTACHMENTS (X)**

- ☒ Geologic Log  
☒ Well Construction Diagram  
☒ Geophysical Log(s)  
☐ Soil/Water Chemical Analyses  
☒ Other Test Pump Data; Well Survey

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

**CERTIFICATION STATEMENT**

1, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.

Layne Christensen Company

NAME (PERSON, FIRM, OR CORPORATION) (TYPED OR PRINTED)

1100 Etiwanda Ave

ADDRESS

Signed

WELL DRILLER/AUTHORIZED REPRESENTATIVE

Fontana

CITY

Ca

STATE

92337

ZIP

6/1/2011

DATE SIGNED

510011

C-57 LICENSE NUMBER

**WELL PERMIT APPLICATION - PRODUCTION WELLS**

DRINKING WATER PROGRAM - ENVIRONMENTAL HEALTH DIV.

5050 COMMERCE DRIVE, BALDWIN PARK, CA 91706 TELE (626) 430-5420 FAX (626) 813-3016

DATE 10/26/10

☒ NEW WELL CONSTRUCTION    ☐ RECONSTRUCTION OR RENOVATION    ☐ DECOMMISSIONING    ☐ OTHER: \_\_\_\_\_  
☐ PRIVATE DOMESTIC    ☐ PRIVATE IRRIGATION    ☐ OTHER: \_\_\_\_\_

Site Address <u>2002 BUENA VISTA ST.</u>		City <u>Duarte</u>	State <u>CA.</u>	Zip Code <u>91010</u>
Township <u>1 N</u>	Range <u>10 W</u>	Section <u>21</u>	Map Book Page/Grid <u>2-366, 62-0 AG/A7</u>	
GPS location: (To be completed after the final seal)				
Type and Size of Production Casing <u>18" x .375 W STEEL, LOW CARBON STEEL</u>				
Sanitary / Annular Sealing Material <u>PORTLAND CEMENT</u>				
Depth of Sanitary / Annular Seal <u>240'</u>				
Conductor Casing Seal <u>50' CEMENT SEAL</u>				

Driller's Name <u>LATNE CHRISTENSEN CO.</u>		Telephone Number <u>909-390-2833</u>	C-57 License Number <u>510011</u>
Address <u>11001 E. WANDA AVE.</u>		City <u>FONTANA</u>	State <u>CA</u>
Zip Code <u>92237</u>			
Well Depth <u>240'</u>		Method of Well Assessment <u>FA</u>	Depth and Number of Perforations <u>909-390-6097</u>
Type and Amount of Sealant	Type of Perforator	Size of Perforations	Method of Upper Seal Pressure Application
Company <u>GEL CONSULTANTS</u>			
Address <u>10510 GOLD CENTER DR.</u>		City <u>RANCHO CORDOVA</u>	State <u>CA</u>
Zip Code <u>95670</u>			
Project Manager <u>RICHARD SHATZ</u>		Telephone Number <u>916-631-4566</u>	

**ATTENTION: WORK PLAN MODIFICATIONS MAY BE REQUIRED IF WELL AND GEOLOGIC CONDITIONS ENCOUNTERED AT THE SITE INSPECTION ARE FOUND TO DIFFER FROM THE SCOPE OF WORK PRESENTED TO THIS DEPARTMENT.**


I hereby agree to comply in every respect with all the regulations of the County Environmental Health Division and with all ordinances and laws of the County of Los Angeles and the State of California pertaining to well construction, reconstruction, and decommissioning. Upon completion of the well and within thirty days thereafter, I will furnish the Environmental Health office with a completion log of the well, giving date drilled, depth of the well, perforations in the casing, and any other data deemed necessary by the County Environmental Health Division.

Signature of C-57 Licensee: [Signature] Printed Name: Robert Brown

**THIS PERMIT IS NOT COMPLETE UNTIL ALL OF THE FOLLOWING REQUIREMENTS ARE SIGNED OFF BY THE DEPUTY HEALTH OFFICER. WELL CONSTRUCTION OR DECOMMISSIONING CANNOT BE INITIATED WITHOUT A WORK PLAN APPROVAL FROM THIS DEPARTMENT.**

\*\*\*\*\* (DEPARTMENT USE ONLY) \*\*\*\*\*

<b>WORK PLAN APPROVAL</b> The approval is valid for 180 days.		<b>FINAL INSPECTION</b> The placement of the sanitary seal must be witnessed by a Deputy Health Officer or the permittee's valid Contractor's Department license for a job completion.	
REFS <u>Juan Brodnig</u> Conditions: <u>On 10/26/10 \$327 was paid for Permit # 890962 to install a production well. Maintain all at Repts.</u> <u>Notify this office at 626-430-5420 or</u> <u>supdr@ezaph.lacounty.gov 48 hrs</u> <u>prior to the work being done.</u>	DATE <u>11/4/10</u>	REFS <u>[Signature]</u> DATE <u>11/4/10</u>	REHS <u>[Signature]</u>

  
 COUNTY OF LOS ANGELES  
**Public Health**

**Vincent Gallegos, B.S., R.E.H.S.**  
 Environmental Health Specialist III  
 Environmental Health  
 Bureau of Environmental Protection  
 Drinking Water Program  
**ADMINISTRATIVE HEADQUARTERS**  
 5050 Commerce Drive  
 Baldwin Park, CA 91706  
 (626) 430-5420 Tel (626) 813-3016 Fax  
 vgallegos@ph.lacounty.gov  
 www.lapublichealth.org/eh

# WELL PERMIT APPLICATION - PRODUCTION WELLS

Cal Am - Clark

00131337

page 2 of 2

Well Location (Include distances from road and major cross streets)

7.627' FROM (CENT) BUENA VISTA AVE.

Projected Start Date 11/1/10

Projected End Date 11/1/11

## WELL LOCATION DIAGRAM

At site inspection, the well location must be staked and clearly marked with the owner's name.

## WELL DECOMMISSIONING DIAGRAM

← WAYS TO NORTH

367' TO SIDE

BUENA VISTA AVE.

X EXISTING WELL

WELL LOCATION

30'

30'

EE

RESIDENTIAL

Provide a scaled drawing (1 inch = 50 feet) with labels and dimensions, indicating property lines, private sewage disposal systems and other possible sources of contamination within 200 feet of the well site. Attach all supporting documents.

## WORK PLAN DETAILS

(Construction or Decommissioning)

DRILL AND SET CONCRETE DRIVE PILE HOLE TO EXIST. PERM. HOLE LOGGING. REAM HOLE AND SET WIRELINE / SCREEN INSIDE. PACK AND GRout ANNUOUS. ADJUST SCREEN TO 15' FROM PUMP & HOLE.

## NOTES/COMMENTS (Department Use Only)



CAL Am

e0131337

May 2011 emi form

# LAYNE CHRISTENSEN COMPANY

## FORMATION REPORT

Date: Dec. 6, 2010 Start Date: \_\_\_\_\_

Customer: \_\_\_\_\_ Completion Date: \_\_\_\_\_

Job Number: 1000-1974 Diameter of Hole: 17 1/2

Well Number: \_\_\_\_\_ Depth of Well: 700 ft

FOOTAGE DESCRIPTION OF FORMATION

FOOTAGE DESCRIPTION OF FORMATION

40-50	Sand & Rock	230-240	Sand & Rock
50-60	Sand & Rock	240-250	Sand & Rock
60-70	Sand & Rock	250-260	Sand & Rock
70-80	Sand & Rock	260-270	Sand & Rock
80-90	Sand & Rock	270-280	Sand & Rock
90-100	Sand & Rock	280-290	Sand & Rock
100-110	Sand & Rock	290-300	Sand & Rock
110-120	Sand & Rock	300-310	Sand & Rock
120-130	Sand & Rock	310-320	Sand & Rock
130-140	Sand & Rock	320-330	Sand & Rock
140-150	Sand & Rock	330-340	Sand & Rock
150-160	Sand & Rock	340-350	Sand & Rock
160-170	Sand & Rock	350-360	Sand & Rock
170-180	Sand & Rock	360-370	Sand Some Rock
180-190	Sand & Rock	370-380	Sand & Rock
190-200	Sand & Rock	380-390	Sand & Rock
200-210	Sand & Rock	390-400	Sand & Rock
210-220	Sand & Rock	400-410	Sand & Rock
220-230	Sand & Rock	410-420	Sand & Rock



CAL AM  
DUARTE CA 00131337  
1000-1974  
**LAYNE CHRISTENSEN COMPANY**  
**FORMATION REPORT**

Date: \_\_\_\_\_ Start Date: \_\_\_\_\_  
Customer: \_\_\_\_\_ Completion Date: \_\_\_\_\_  
Job Number: 812-360-5497 Diameter of Hole: \_\_\_\_\_  
Well Number: \_\_\_\_\_ Depth of Well: \_\_\_\_\_

FOOTAGE DESCRIPTION OF FORMATION

FOOTAGE DESCRIPTION OF FORMATION

420-430	Sand & Rock	410-420	Sand & Rock
430-440	Sand & Rock	620-630	Sand & Rock
440-450	1 1/2" Sand-Rock	630-640	Sand & Rock
450-460	Sand & Rock	640-650	Sand & Rock
460-470	Sand & Rock	650-660	Sand & Rock
470-480	Sand & Rock	660-670	Sand & Rock
480-490	Clay Sand & Rock	670-680	Sand & Rock
490-500	Sand & Rock	680-690	Sand & Gravel
500-510	Sand 1 1/2" Rock	690-700	Sand & Gravel
510-520	Sand & Rock	700-710	Sand Gravel some Cobbles
520-530	Sand & Rock	710-720	Sand Gravel some Cobbles
530-540	Sand & Rock	720-734	Sand Gravel some Cobbles
540-550	Sand & Rock		
550-560	Sand & Rock		
560-570	Sand & Rock		
570-580	Sand & Rock		
580-590	Sand & Rock		
590-600	Sand & Rock		
600-610	Sand & Rock		

# Layne Christensen Company

00131337

Date: 4-7-11 Page 1

Customer: NEW WELL #1

Job No. 27- 1000 1974

Meter 10" X 1000

Static level 200.00 Feet

Hours/Page 5.0

Airline depth            Feet

Total hours 5.0

G.P.D.           

Operator: J. ALBA

Time	P.P.M.	G.P.M.	Pumping Level	Draw-down	Engine R.P.M.	Specific Capacity	Comments	FAU	TSS
8:30			200.0				METER READING. 023794.0		
START 9:33									
10:00	33.37	529.62	202.0	2.0	1201	264.81	LT. COLOR QT 809.3		
10:15	2.82	813.33	202.95	2.95	1253	275.70	CLR QT 821.5		
10:30	3.53	1053.33	204.1	4.1	1304	256.91	CLR VALVE OVER TO WASH 837.3		
10:45	2.12	1280.0	204.85	4.85	1357	263.91	CLR QT 856.5		
11:00	4.59	1580.0	206.16	6.16	1404	256.49	CLR QT 880.2		
11:15	2.82	1760.0	207.0	7.0	1457	251.42	CLR 906.6		
11:30	0.35	1766.66	207.0	7.0	1457	252.38	CLR QT 933.1		
11:48	2.94	1933.33	207.78	7.78	1514	248.50	CLR QT 967.9		
12:00	1.76	2083.33	208.45	8.45	1563	246.54	CLR 992.9		
			SURGE X 3						
12:06			RESUME Pumping				023993.7		
12:21	3.53	686.66	202.51	2.51	1213	273.57	CLR 024004.0		
			SURGE X 3						
12:26			RESUME Pumping				41.9		
12:41	2.82	746.66	202.5	2.5	1212	298.66	CLR 15.2		
			SURGE X 3						
12:46			RESUME Pumping				16.0		
1:01	1.76	686.66	202.45	2.45	1212	280.27	CLR QT 26.3		
			SURGE X 3						
1:06			RESUME Pumping				27.4		
1:21	2.47	840.0	203.1	3.1	1252	270.96	CLR 40.2		
			SURGE X 7						
1:26			RESUME Pumping				41.5		
1:41	1.76	833.33	203.1	3.1	1251	268.81	CLR 54.0		
			SURGE X 3						
1:46			RESUME Pumping				55.0		
2:01	2.12	833	203.1	3.1	1251	268.81	CLR QT 67.5		
2:06			SURGE X 3 RESUME Pumping				68.5		
2:21	0.35	1073.33	203.87	3.87	1305	277.34	CLR 84.6		

e0121337

Customer: NEW WELL #1

Meter 10 x 1000

Static level 200.00 Feet

**Airline depth\_\_\_\_\_Feet**

Hours/Page 1.5

**Total hours** 6.5

G.P.D. 381,000.0

Operator:                     HUBA                    

[illegible]

# Layne Christensen Company

00131337

Date: 4-8-11 Page 3

Customer: New well #1

Job No. 27-1000-1974

Meter 10" X 1000

Static level 198.00 Feet

Hours/Page 5 1/2

Airline depth            Feet

Total hours 12

Operator: R. WEBER

G.P.D. 461,900

develop

Time	P.P.M.	G.P.M.	Pumping Level	Draw-down	Engine R.P.M.	Specific Capacity	Comments	FAU	TSS
10:40	Start	-	All measurements		275	75' A.G.S	meter-24176.5		
1:55	0.28	1067	201.75	3.75'	1305	285	CLEAR-Sx3 192.5		
11:02	resume						194.1		
1:17	0.18	1527	203.63	5.63'	1405	271	CIR-Sx3 217		
1:22	resume						218.5	0	0
1:37	0.18	1533	203.67	5.67'	1400	270	CIR-Sx3 241.5		
1:41	resume						242.5		
1:56	0.18	1700	204.32	6.32'	1450	269	CIR-Sx3 268		
2:00	resume						269.3		
1:15	0.18	1693	204.35	6.35'	1453	267	CIR-Sx3 294.7		
1:20	resume						296.9		
1:35	0.18	1713	204.35	6.35'	1457	270	CIR-Sx3 322.6		
1:40	resume						324.9		
1:55	0.18	1707	204.38	6.38'	1455	268	CIR-Sx3 350.5		
1:00	resume						353		
1:15	0.11	1873	204.91	6.91'	1505	271	CIR-Sx3 381.1		
1:20	resume						382.2		
1:35	0.076	1873	204.94	6.94'	1507	270	CIR-Sx3 410.3		
1:40	resume						412.4	0	0
1:55	0.076	1873	204.95	6.95'	1507	270	CIR-Sx3 440.5		
2:00	resume						443.6		
1:15	0.076	1860	204.80	6.80'	1503	274	CIR-Sx3 471.5		
1:20	resume						473.9		
1:35	0.18	1973	205.40	7.40'	1550	266	CIR-Sx3 503.5		
1:51	resume						505.4		
3:06	0.19	1980	205.35	7.35'	1550	269	CIR-Sx3 535.1		
1:11	resume						537.8		
1:26	0.18	2133	206.00	8.00'	1600	267	CIR-Sx3 569.8		
1:31	resume						572.5		
1:46	0.076	2133	205.95	7.95'	1600	268	CIR-Sx3 604.5		
1:53	resume						606.5		
4:08	0.076	2127	205.93	7.93'	1600	268	CIR-shut down 24638.4		

# Layne Christensen Company

e0131337

Date: 4-9-11 Page 4

Customer: New well #1

Job No. 1000-1974

Meter 10 X 1000

Static level 197.45 Feet

Hours/Page 5 1/2

Airline depth            Feet

Total hours 17 1/2

G.P.D.           

Operator: R. WEBER

Time	P.P.M.	G.P.M.	Pumping Level	Draw-down	Engine R.P.M.	Specific Capacity	Comments	FAU	TSS
7:05	START	All measurements		2.75'	AGS		meter 29681.9		
120	0.11	2140	205.25'	7.80'	1605	274	CLEAR -Sx3 674		
125	resume	* AIR IN WATER					677		
140	0.11	2273	205.92'	8.47'	1656	268	CLR-Sx3 711.1		
145	resume						713.5		
8:05	0.11	2275	205.98'	8.53'	1653	267	CLR-Sx3 759		
113	resume						764.6		
128	0.11	2260	205.95'	8.50'	1654	266	CLR-Sx3 778.5	0	0
133	resume						801.1		
148	0.38	2387	206.45'	9.00'	1702	265	CLR-Sx3 836.9		
153	resume						840.4		
9:08	11	2640	207.65'	10.20'	1805	259	CLR-Sx3 880		
113	resume						883.5		
128	0.19	2380	206.38'	8.93'	1700	267	CLR-Sx3 919.2		
138	resume						924.5		
153	0.19	2400	206.42'	8.97'	1710	268	CLR-Sx3 960.5		
158	resume						963.5		
10:13	0.11	2513	206.95'	9.50'	1753	265	CLR-Sx3 25001.2		
118	resume						204.6		
133	0.11	2493	206.87'	9.42'	1747	265	CLR-Sx3 042		
139	resume						045.5		
154	0.19	2533	207.10'	9.65'	1753	263	CLR-Sx3 083.5		
159	resume						087.1		
11:14	0.11	2700	207.88'	10.43'	1830	259	CLR-Sx3 127.6		
119	resume						131.3		
134	0.11	2720	207.95'	10.50'	1840	259	CLR 1721		
149	0.07	2713	208.00'	10.55'	1840	257	CLR-Sx3 212.8		
155	resume						218		
12:10	0.11	2700	208.00'	10.55'	1832	256	CLR-Sx3 258.5		
115	resume						262.5		
130	0.11	2700	208.00'	10.55'	1825	256	CLR-Sx3 303		
136	resume						306		

*Layne Christensen Company*

e0131337

Date: 4-9-11 Page 5

Customer: New well

Job No. ~~87~~-1000-1974

Meter 10 X 1000

Static level 197.45 Feet

**Airline depth** \_\_\_\_\_ **Feet**

Hours/Page 4

**Total hours** 21 1/2

G.P.D. 1,119,300

Operator: R. WEBER

develop

[illegible]

# Layne Christensen Company

e0131337

Date: 4-10-11 Page 6

Customer: Buena Vista new well

Job No. 27-1000-1974

Meter 10X 1000

Static level 196.55' Feet

Hours/Page 4

Airline depth \_\_\_\_\_ Feet

Total hours 25 1/2

G.P.D. \_\_\_\_\_

Operator: R. WEBER

Stop test

Time	P.P.M.	G.P.M.	Pumping Level	Draw-down	Engine R.P.M.	Specific Capacity	Comments	FAU	TSS
7:30	START						25762		
7:32	1.1	1000	200.15'	3.60'	1308		764 - CLEAR - AIR		
7:34	TRACE	1150	200.36'	3.81'	1320	302	766.3 CIR - SI. AIR		
7:36	0	1150	200.43'	3.88'	1320	296	768.6 CIR		
7:38	0	1250	200.43'	3.88'	1320	322	771.1 Adj Q ↓		
7:40	0	1200	200.38'	3.83'	1312	313	773.4 CIR - SI. AIR		
7:45	0	1040	200.33'	3.98'	1312	275	778.6 CIR		
7:50	0	1200	200.36'	3.81'	1312	315	784.6 CIR		
7:55	0	1100	200.37'	3.82'	1312	288	790.1 CIR		
8:00	0	1100	200.35'	3.80'	1312	289	795.6 CIR		
8:10	0	1130	200.45'	3.90'	1312	290	806.9 CIR (pH 8.0)	0	0
8:20	0	1130	200.43'	3.88'	1312	291	818.2 CIR		
8:30	0	1120	200.46'	3.91'	1312	286	829.4 CIR		
8:45	0	1113	200.39'	3.84'	1312	290	846.1 CIR		
9:00	0	1140	200.40'	3.85'	1312	296	863.2 CIR		
9:15	0	1093	200.45'	3.90'	1312	280	879.6 CIR		
9:30	0	1133	200.45'	3.90'	1312	291	25896.6 Adj Q ↑		
9:32	TRACE	1700	202.22'	5.67'	1426	300	900 CIR - AIR		
9:34	0	1650	202.21'	5.66'	1415	292	903.3		
9:36	0	1400	202.17'	5.62'	1415	249	906.1		
9:38	0	1700	202.17'	5.62'	1415	302	909.5		
9:40	0	1600	202.20'	5.65'	1415	283	912.7		
9:45	0	1620	202.21'	5.66'	1415	286	920.8		
9:50	0	1540	202.25'	5.70'	1415	270	928.5		
9:55	0	1620	202.25'	5.70'	1415	284	936.6		
10:00	0	1640	202.25'	5.70'	1415	288	944.8		
10:10	0	1610	202.25'	5.70'	1415	282	960.9		
10:20	0	1580	202.26'	5.71'	1415	277	976.7		
10:30	0	1600	202.30'	5.75'	1415	278	992.7		
10:45	0	1587	203.33'	5.78'	1415	275	26016.5		
11:00	0	1607	202.37'	5.82'	1415	276	040.6		
11:30	0	1597	202.45'	5.90'	1415		26088.5 Q ↑		

1122 spm Aug

15996 f/m Aug



# Layne Christensen Company

00131337

Date: 4-10-11 Page 7

Customer: Buena Vista well

Job No. 28-1000-1974

Meter 10 X 1000

Static level 196.55 Feet

Airline depth            Feet

Hours/Page 4

Total hours 29 1/2

G.P.D. 16,000

Operator: R. Weber

Step test (cont.)

Time	P.P.M.	G.P.M.	Pumping Level	Draw-down	Engine R.P.M.	Specific Capacity	Comments	FAU	TSS
11:32	0	2250	204.70	8.15'	1626	276	26093		
1:34	0	2150	204.71	8.16'	1626	250	097.3 - CLR - AIR		
1:36	0	2300	204.71	8.16'	1626	282	101.9		
1:38	0	2100	204.71	8.16'	1626	257	106.1		
1:40	0	2050	204.71	8.16'	1626	251	110.2 Adj Q↑		
1:45	0	2320	204.82	8.27'	1633	281	121.8		
1:50	0	2200	204.85	8.30'	1633	265	132.8		
1:55	0	2400	204.85	8.30'	1633	289	144.8		
12:00	0	2040	204.87	8.32'	1633	245	155		
1:10	0	2210	204.81	8.26'	1633	268	177.1		
1:20	0	2220	204.93	8.38'	1633	265	199.3		
1:30	0	2240	204.90	8.35'	1633	268	221.7		
1:45	0	2220	204.85	8.30'	1633	267	255		
1:00	0	2207	204.93	8.38'	1633	263	288.1		
1:15	0	2227	204.85	8.30'	1633	268	321.5		
1:30	0	2213	204.88	8.33'	1633	266	26354.7 Q↑		
1:32	0.07	2650	206.77	10.22'	1824	259	26360		
1:34	0	2750	206.83	10.28'	1824	268	365.5		
1:36	0	2700	206.87	10.32'	1824	262	370.9		
1:38	0	2600	206.88	10.33'	1824	252	376.1		
1:40	0	2750	206.88	10.33'	1824	266	381.6		
1:45	0	2680	206.91	10.36'	1824	259	395		
1:50	0	2680	206.95	10.40'	1824	258	408.4 Adj Q↑		
1:55	0	2720	207.02	10.47'	1825	260	422		
2:00	0	2680	207.01	10.46'	1825	256	435.4		
2:10	0	2700	207.08	10.53'	1825	256	462.4		
2:20	0	2710	206.97	10.42	1825	261	489.5		
2:30	0	2680	206.98	10.43	1825	258	516.3		
2:45	0	2700	207.00	10.45'	1825	258	556.8		
3:00	0	2693	207.20	10.65'	1825	253	597.2		
3:15	0	2700	207.19	10.64'	1825	254	637.7		
3:30	0	2693	207.10	10.55'	1825	255	26678.1 Shutdown		

2210 gpm Aug.

2695 gpm Aug.

# Layne Christensen Company

e 0131337

Date: 4-12-11 Page 8

Customer: NEW WELL

Job No. 27- 1000-1974

Meter 10" X 1000 GPM S

Static level 196.05 Feet

Hours/Page 13.0

Airline depth            Feet

Total hours 42.5

Operator: J. AUBA

G.P.D.           

Time	P.P.M.	G.P.M.	Pumping Level	Draw-down	Engine R.P.M.	Specific Capacity	24 HRS CONSTANT RATE Comments	FAU	TSS
8:30			196.05				METER READING 026678.4		
START 9:00					1628				
9:05	5.3	2240.0	205.75	9.3	1628	240.86	CLR 690.5		
9:10	1.06	2260.0	204.21	8.16	1628	276.96	CLR 701.5		
9:15	TRACE	2200.0	204.3	8.25	1630	266.66	CLR 712.8		
9:20	⊖	2220.0	204.24	8.25	1630	267.79	CLR 723.9		
9:25	⊖	2200.0	204.72	8.28	1630	265.70	CLR 734.9		
9:30	⊖	2210.0	204.33	8.28	1630	266.90	CLR 746.0		
9:40	⊖	2220.0	204.35	8.30	1630	265.06	CLR 768.2		
9:50	⊖	2240.0	204.35	8.30	1630	269.87	CLR 790.6		
10:00	⊖	2240.0	204.36	8.31	1630	269.85	CLR 812.0		
10:15	⊖	2213.33	204.38	8.33	1630	265.70	CLR 846.2		
10:30	⊖	2220.0	204.40	8.35	1630	265.86	CLR 879.5		
10:45	⊖	2233.33	204.40	8.35	1630	267.46	CLR 913.0		
11:00	⊖	2220.0	204.40	8.35	1630	265.86	CLR 146.3		
11:15	⊖	2220.0	204.40	8.35	1630	265.86	CLR 26979.6		
11:30	⊖	2233.33	204.40	8.35	1628	267.46	CLR 27013.1		
11:45	⊖	2213.33	204.40	8.35	1628	265.06	CLR 46.3		
12:00	⊖	2240.0	204.40	8.35	1628	269.26	CLR 79.9		
12:30	⊖	2220.0	204.40	8.35	1628	265.86	CLR 146.5		
1:00	⊖	2220.0	204.40	8.35	1628	265.86	CLR 213.1		
1:30	⊖	2216.66	204.40	8.35	1628	265.46	CLR 279.6		
2:00	⊖	2216.66	204.40	8.35	1628	265.46	CLR 346.7		
2:30	⊖	2223.33	204.40	8.35	1628	266.26	CLR 412.8		
3:00	⊖	2220.0	204.40	8.35	1628	265.86	CLR 479.4		
4:00	⊖	2226.66	204.40	8.35	1628	266.66	CLR 613.0		
5:00	⊖	2216.66	204.40	8.35	1628	265.46	CLR 746.0		
6:00	⊖	2221.66	204.40	8.35	1628	266.06	CLR 27879.3		
7:00	⊖	2225.0	204.42	8.37	1628	265.83	CLR 028012.8		
8:00	⊖	2228.33	204.45	8.4	1628	265.27	CLR 028146.5		
9:00	⊖	2216.66	204.27	8.22	1628	269.66	CLR 028279.5		
10:00	⊖	2208	204.39	8.34	1628	264.74	CLR 028412		

e0131237

Customer: New Well

Job No. 27-1000-1974

Meter 10 x 1000

Static level 196.05 Feet  
Airline depth \_\_\_\_\_ Feet

Hours/Page 11.0

**Total hours** 53.5

G.P.D. 3,200,500.0

Operator: J. Hernandez

[illegible]

# Pacific Surveys


a full service geophysical well logging company

## Video Survey Report

e0131837

<b>Company:</b>	Layne Christensen	<b>Date:</b>	29-Apr-11
<b>Well:</b>	Buena Vista Well	<b>Run No.</b>	One
<b>Field:</b>	Duarte	<b>Job Ticket:</b>	15929
<b>State:</b>	California	<b>Total Depth:</b>	718 ft
		<b>Water Level:</b>	203 ft
<b>Location:</b>	2002 Buena Vista St.	<b>Oil on Water:</b>	No
	GPS: N34o 07.710' W117o 58.560'	<b>Operator:</b>	Ridder
<b>Zero Datum:</b>	Ground Level	<b>Side-Scan</b>	
<b>Reason for Survey:</b>	New Well Construction	<b>Dead Space</b>	21"

Depth	Remarks	Perforation:	
0.0 ft	Start survey at ground level	Full-Flo Louvers:	300.00 ft to 340.00ft
202.7 ft	SWL: water is clear to cloudy. Visibility adequate		360.00 ft to 475.00ft
297.0 ft	Water clears distinctly		495.00 ft to 700.00ft
302.6 ft	Perfs: all appear open and in good shape. Joint is at 301.2 ft		
340.9 ft	Perfs end: entire interval is open		
362.8 ft	Perfs: all appear open and in good shape.		
473.5 ft	Perfs end: entire interval is open		
491.5 ft	Perfs: all appear open and in good shape		
550.0 ft	Slight bio-growth between column of louvers		
701.6 ft	Perfs end: entire interval is open		
718.0 ft	Bottom of light bar stops: in very soft fill. End survey		
		<b>Casing Size:</b>	
		18"	0.00 ft to 720.00ft
		<b>Casing Material</b>	N/A
		<b>Screen Material</b>	N/A



# GYROSCOPIC SURVEY

County LOS ANGELES State CA

## VIDEO SURVEY

Elevation  
K.B.  
D.F.  
G.L.

— 100 —

---

\_\_\_\_\_

---

---

---

---

---

--	--

[illegible][illegible]

---

---

---

[illegible]

Record

From	To
------	----


[illegible][illegible]

**Bottom**

--	--

151


120

[illegible]

--	--

CROSS - SECTION  
(Displacement in ft)

e013(337







CLOSURE SECTIONS  
( True Depth vs. Displacement (ft) )

e0131337

N - S SECTION



W - E SECTION




Misalignment Diameter = 4.40 (in)

Pump Depth = 360.0 (ft)

Max Pump Diameter for ID of 18.00 = 13.60 (in)


DOG LEG  
(True Depth(ft) vs Deg/100ft)

e0131337



IN THE PLANE OF CLOSURE  
(True Depth vs Displacement (ft))

e 013/337



## TVD Report (Minimum Curvature Method)

e 0131337

Database File: 15929.db  
 Dataset Pathname: \\\\_tvd\_1  
 Dataset Creation: Fri Apr 29 11:55:39 2011

Meas. Depth	Incline	Azimuth	TVD	North	East	Dogleg	Closure Dis	Closure Dir	Vert. Sec.
(ft)			(ft)	(ft)	(ft)		(ft)		(ft)
Vertical Section Direction 0.00									
0.0	0.00	149.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10.0	0.00	147.91	10.00	0.00	0.00	0.00	0.00	0.00	0.00
20.0	0.00	152.96	20.00	0.00	0.00	0.00	0.00	0.00	0.00
30.0	0.00	162.66	30.00	0.00	0.00	0.00	0.00	0.00	0.00
40.0	0.00	153.17	40.00	0.00	0.00	0.00	0.00	0.00	0.00
50.0	0.00	155.01	50.00	0.00	0.00	0.00	0.00	0.00	0.00
60.0	0.00	154.98	60.00	0.00	0.00	0.00	0.00	0.00	0.00
70.0	0.00	153.12	70.00	0.00	0.00	0.00	0.00	0.00	0.00
80.0	0.00	152.34	80.00	0.00	0.00	0.00	0.00	0.00	0.00
90.0	0.00	150.18	90.00	0.00	0.00	0.00	0.00	0.00	0.00
100.0	0.00	145.83	100.00	0.00	0.00	0.00	0.00	0.00	0.00
110.0	0.03	155.89	110.00	-0.00	0.00	0.30	0.00	-24.11	-0.00
120.0	0.03	147.48	120.00	-0.01	0.00	0.04	0.01	-26.91	-0.01
130.0	0.03	148.18	130.00	-0.01	0.01	0.00	0.01	-29.02	-0.01
140.0	0.03	152.46	140.00	-0.02	0.01	0.02	0.02	-29.21	-0.02
150.0	0.03	145.39	150.00	-0.02	0.01	0.04	0.02	-29.62	-0.02
160.0	0.03	148.01	160.00	-0.02	0.01	0.01	0.03	-30.29	-0.02
170.0	0.03	142.49	170.00	-0.03	0.02	0.03	0.03	-30.98	-0.03
180.0	0.03	135.93	180.00	-0.03	0.02	0.03	0.04	-32.28	-0.03
190.0	0.03	134.34	190.00	-0.04	0.02	0.01	0.04	-33.76	-0.04
200.0	0.01	137.05	200.00	-0.04	0.03	0.20	0.05	-34.58	-0.04
210.0	0.02	137.76	210.00	-0.04	0.03	0.10	0.05	-34.99	-0.04
220.0	0.09	130.76	220.00	-0.05	0.04	0.70	0.06	-37.06	-0.05
230.0	0.08	131.91	230.00	-0.06	0.05	0.10	0.07	-39.37	-0.06
240.0	0.10	138.77	240.00	-0.07	0.06	0.23	0.09	-40.22	-0.07
250.0	0.19	143.39	250.00	-0.09	0.07	0.91	0.12	-39.78	-0.09
260.0	0.12	145.00	260.00	-0.11	0.09	0.70	0.14	-39.06	-0.11
270.0	0.16	150.71	270.00	-0.13	0.10	0.42	0.17	-37.99	-0.13
280.0	0.17	144.37	280.00	-0.16	0.12	0.21	0.20	-37.19	-0.16
290.0	0.17	151.60	290.00	-0.18	0.13	0.21	0.22	-36.51	-0.18
300.0	0.22	170.07	300.00	-0.21	0.14	0.80	0.26	-34.12	-0.21
310.0	0.34	176.92	310.00	-0.26	0.15	1.24	0.30	-29.70	-0.26
320.0	0.39	174.98	320.00	-0.32	0.15	0.51	0.36	-25.30	-0.32
330.0	0.23	176.36	330.00	-0.38	0.16	1.60	0.41	-22.62	-0.38
340.0	0.23	167.09	340.00	-0.42	0.16	0.37	0.45	-21.35	-0.42
350.0	0.13	168.48	350.00	-0.45	0.17	1.00	0.48	-20.77	-0.45
360.0	0.19	183.62	360.00	-0.48	0.17	0.73	0.51	-19.79	-0.48
370.0	0.18	192.75	370.00	-0.51	0.17	0.31	0.53	-18.18	-0.51
380.0	0.17	203.90	380.00	-0.54	0.16	0.35	0.56	-16.33	-0.54
390.0	0.38	213.51	390.00	-0.58	0.13	2.14	0.59	-12.96	-0.58
400.0	0.57	207.71	400.00	-0.65	0.09	1.96	0.66	-8.03	-0.65
410.0	0.37	195.26	410.00	-0.73	0.06	2.23	0.73	-4.73	-0.73
420.0	0.32	205.14	420.00	-0.78	0.04	0.78	0.78	-2.90	-0.78
430.0	0.33	205.59	430.00	-0.83	0.02	0.10	0.83	-1.06	-0.83
440.0	0.26	201.63	440.00	-0.88	-0.01	0.73	0.88	0.35	-0.88
450.0	0.20	188.42	450.00	-0.92	-0.02	0.80	0.92	1.02	-0.92
460.0	0.05	172.99	460.00	-0.94	-0.02	1.52	0.94	1.12	-0.94
470.0	0.04	125.99	470.00	-0.95	-0.02	0.37	0.95	0.91	-0.95
480.0	0.05	124.16	480.00	-0.95	-0.01	0.10	0.95	0.52	-0.95
490.0	0.19	119.34	490.00	-0.96	0.01	1.40	0.96	-0.56	-0.96

Meas. Depth	Incline	Azimuth	TVD	North	East	Dogleg	Closure Dis	Closure Dir	Vert. Sec.
(ft)			(ft)	(ft)	(ft)		(ft)		(ft)
Vertical Section Direction 0.00									
500.0	0.20	108.89	500.00	-0.98	0.04	0.37	0.98	-2.37	-0.98
510.0	0.28	109.19	510.00	-0.99	0.08	0.80	0.99	-4.63	-0.99
520.0	0.25	116.04	520.00	-1.01	0.12	0.44	1.01	-6.95	-1.01
530.0	0.21	144.31	530.00	-1.03	0.15	1.19	1.04	-8.44	-1.03
540.0	0.32	167.71	540.00	-1.07	0.17	1.52	1.09	-8.98	-1.07
550.0	0.34	165.50	550.00	-1.13	0.18	0.24	1.14	-9.21	-1.13

EO131337

560.0	0.38	171.49	560.00	-1.19	0.20	0.55	1.21	-9.32	-1.19
570.0	0.31	173.17	570.00	-1.25	0.20	0.71	1.27	-9.24	-1.25
580.0	0.32	178.80	580.00	-1.31	0.21	0.33	1.32	-9.02	-1.31
590.0	0.41	178.13	590.00	-1.37	0.21	0.90	1.38	-8.68	-1.37
600.0	0.38	167.25	600.00	-1.44	0.22	0.81	1.45	-8.61	-1.44
610.0	0.32	153.17	610.00	-1.49	0.24	1.04	1.51	-9.03	-1.49
620.0	0.31	151.05	620.00	-1.54	0.26	0.15	1.56	-9.68	-1.54
630.0	0.30	157.76	630.00	-1.59	0.29	0.37	1.62	-10.20	-1.59
640.0	0.29	162.67	640.00	-1.64	0.30	0.27	1.67	-10.49	-1.64
650.0	0.28	170.59	650.00	-1.69	0.32	0.41	1.72	-10.58	-1.69
660.0	0.41	184.37	660.00	-1.75	0.32	1.53	1.78	-10.26	-1.75
670.0	0.31	190.43	669.99	-1.81	0.31	1.07	1.84	-9.68	-1.81
680.0	0.32	191.95	679.99	-1.86	0.30	0.13	1.89	-9.09	-1.86
690.0	0.40	191.15	689.99	-1.92	0.29	0.80	1.95	-8.44	-1.92
700.0	0.45	172.66	699.99	-2.00	0.28	1.45	2.02	-8.08	-2.00
710.0	0.46	173.66	709.99	-2.08	0.29	0.13	2.10	-8.04	-2.08



State of California  
**Well Completion Report**  
 Form DWR 188 Complete 9/14/2016  
 WCR2016-006450

Owner's Well Number Lemon Well Date Work Began 01/04/2016 Date Work Ended 08/24/2016  
 Local Permit Agency LA County Department of Public Health, Department of Health Services, Drinking Water Program  
 Secondary Permit Agency \_\_\_\_\_ Permit Number SR0046576 Permit Date 10/01/2015

Well Owner (must remain confidential pursuant to Water Code 13752)		Planned Use and Activity
Name <u>XXXXXXXXXXXXXXXXXXXX</u>	Activity <u>New Well</u>	
Mailing Address <u>XXXXXXXXXXXXXXXXXXXX</u> <u>XXXXXXXXXXXXXXXXXXXX</u>	Planned Use <u>Water Supply Public</u>	
City <u>XXXXXXXXXXXXXXXXXXXX</u> State <u>XX</u> Zip <u>XXXXX</u>		

Well Location	
Address <u>1271 E Lemon DR</u>	APN <u>8527-025-020</u>
City <u>Bradbury</u> Zip <u>91008</u> County <u>Los Angeles</u>	Township <u>01 N</u>
Latitude <u>34</u> <u>08</u> <u>49.4</u> <u>N</u> Longitude <u>-117</u> <u>58</u> <u>35.5</u> <u>W</u>	Range <u>10 W</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>30</u>
Dec. Lat. <u>34.1470556</u> Dec. Long. <u>-117.9765278</u>	Baseline Meridian <u>San Bernardino</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy <u>&gt;50 Ft</u> Location Determination Method _____	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	Water Level and Yield of Completed Well
Orientation <u>Vertical</u> Specify _____	Depth to first water <u>374</u> (Feet below surface)
Drilling Method <u>Reverse Circulation</u> Drilling Fluid <u>Bentonite</u>	Depth to Static _____
Total Depth of Boring <u>900</u> Feet	Water Level <u>374</u> (Feet) Date Measured <u>08/09/2016</u>
Total Depth of Completed Well <u>900</u> Feet	Estimated Yield* <u>380</u> (GPM) Test Type <u>Pump</u>
	Test Length <u>180</u> (Hours) Total Drawdown <u>290</u> (feet)
	*May not be representative of a well's long term yield.

Geologic Log - Free Form		
Depth from Surface Feet to Feet		Description
0	100	Sand, Gravel
100	160	Sand, Gravel, Trace Clay
160	180	Sand, Gravel
180	220	Sand, Clay, Gravel
220	260	Sand, Gravel
260	280	Sand
280	360	Clay, Sand
360	380	Sand, Clay
380	400	Sand
400	430	Rock
430	440	Rock, Sand, Gravel, Clay
440	460	Clay, Sand, Gravel
460	500	Sand, Gravel, Clay
500	520	Gravel, Clay
520	560	Sand, Gravel, Clay

560	590	Rock, Trace Clay, Hard Sand
590	610	Rock, Hard Sand
610	620	Hard Rock
620	630	Clay Rock
630	690	Sand, Rock
690	710	Rock, Sand
710	720	Clay
720	740	Clay, Rock, Sand
740	750	Clay Gravel
750	780	Rock, Sand, Gravel
780	790	Rock, Gravel, Sand, Trace Clay
790	810	Rock, Sand, Gravel
810	820	Rock, Sand, Gravel, Trace Clay
820	830	Rock, Sand, Gravel
830	840	Rock, Sand, Gravel, Trace Clay
840	850	Rock, Sand, Gravel
850	870	Sand, Gravel, Trace Clay
870	880	Sand, Clay, Trace Gravel
880	900	Sand, Gravel, Rock

### Casings

Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	548	Blank	Mild Steel	Nominal Size: 20 in.   Thickness: 5/16 in.   OD: 20 in.	0.3125	20			
1	548	550	Other: Dielectric Coupling	Other	N/A	2	20			
1	550	840	Screen	Spiral Weld Stainless Steel	Nominal Size: 20 in.   Thickness: 5/16 in.   OD: 20-5/8 in.	0.3125	20.625	Louver	0.09	
1	840	842	Other: Dielectric Coupling	Other	N/A	2	20			
1	842	860	Blank	Low Carbon Steel	Nominal Size: 20 in.   Thickness: 5/16 in.   OD: 20-5/8 in.	0.3125	20.625			
1	860	900	No Casing Installed	Other	N/A					

### Annular Material

Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	520	Cement	10.3 Sack Mix		
520	530	Other Fill	See description.		Transition Sand
530	900	Filter Pack	Other Gravel Pack		

**Other Observations:**

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	50	40
50	900	30

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	SOUTHWEST PUMP & DRILLING INC		
	Person, Firm or Corporation		
53-381 HIGHWAY 111	COACHELLA	CA	92236
Address	City	State	Zip
Signed	<i>electronic signature received</i>	09/12/2016	723919
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

Attachments
21008 ELOG RUN 2.pdf - Geologic Log
20973_ElogcRUN 1.pdf - Geologic Log
21021 ELOG RUN 3.pdf - Geologic Log

DWR Use Only									
CSG #	State Well Number			Site Code	Local Well Number				
				N					W
Latitude Deg/Min/Sec					Longitude Deg/Min/Sec				
TRS: APN:									