

R.P. CONSTRUCTORS, INC.
9455 IH 35 N
NEW BRAUNFELS, TEXAS 78130-7132
(512) 392-5111 * FAX (512) 392-5121

EDINBURG WEST WTP RESERVOIR PROJECT PRE-BID QUESTIONS / COMMENTS

Submitted: June 29,2020

- 1) Q Specification 05522, Aluminum Railing, calls to “provide PVDF on the handrails. We cannot find any manufacturer that coats their handrail with PVDF. Will Anodized coating be sufficient?
A Yes

- 2) Q Can Fiberglass Grating be used instead of Stainless Steel Grating?
A You may use either Stainless Steel Grating per specification Document 05522 or Fiberglass Grating per specification Document 06620 Fiberglass Grate (Adm 2)