



- NOTES:
1. ALL PHASE, NEUTRAL, & GROUNDING CONDUCTORS SHALL BE INSULATED.
 2. SERVICE WIRE SIZE SHALL COMPLY WITH NATIONAL ELECTRIC CODE
 3. WHEN INSTALLING A 480Y/277 SERVICE, METERING AND DISCONNECT INSTALLATION TO BE DETERMINED BY F.E.D. MANAGER AND ENGINEER.

NOTE: FLORENCE ELECTRICITY DEPT. CAN ONLY SUPPLY A MAXIMUM OF 225KVA OVERHEAD CAPACITY. ANY SERVICE THAT REQUIRES MORE CAPACITY MUST APPLY FOR UNDERGROUND SERVICE

	FLORENCE UTILITIES ELECTRICITY	
	SCALE	APPROVED BY
DATE 01/06/22		T. PIGG
OVERHEAD SERVICE FOR COMMERCIAL BUSINESS (SERVICE THROUGH ROOF)		
W.O.#		DRAWING NUMBER S-6100
REVISED DATE	INITIALS	