



NOTES:
 SIDEWALK SHALL BE CONSTRUCTED OF 4000 PSI CONCRETE AND HAVE A NON-SLIP BROOM FINISH SURFACE. FINISH SHALL BE PERPENDICULAR TO DIRECTION OF TRAFFIC.

SIDEWALK SHALL BE CONSTRUCTED IN ACCORDANCE WITH CHAPTER 1462 - CONCRETE SURFACES AND CHAPTER 1480 - SIDEWALK CONSTRUCTION OF THE CODIFIED ORDINANCES OF NORTH ROYALTON, OHIO.
 SEE CHAPTER 1246.03 FOR WIDTH OF SIDEWALKS LOCATED OTHER THAN PUBLIC STREETS (I.E. LOCAL COLLECTOR, MAJOR ARTERIAL...)

SIDEWALK THICKNESSES:
 4" - TYPICAL
 6" - RESIDENTIAL DRIVE APRONS (THRU DRIVEWAY)
 8" - COMMERCIAL DRIVE APRONS (THRU DRIVEWAY)

CONCRETE SIDEWALK DETAIL - CITY OF NORTH ROYALTON

NOT TO SCALE