

## **STORM WATER COMMITTEE MINUTES SEPTEMBER 5, 2023**

The Storm Water Committee meeting was held on September 5, 2023 at North Royalton City Hall, 14600 State Road. The meeting was called to order at 8:28 p.m.

**PRESENT:** **Committee Members:** Chair Linda Barath, Vice Chair John Nickell, Mike Vos; **Council:** Paul Marnecheck, Joanne Krejci, Jeremy Dietrich, Heidi Webber; **Administration:** Mayor Larry Antoskiewicz, City Engineer Justin Haselton, Law Director Tom Kelly, Finance Director Jenny Esarey, Service Director Nick Cinquepalmi, Wastewater Superintendent Mark Smith; **Other:** Joel Spatz, Anthony Santangelo, Vincent Weimer, Jeff Hess, Kevin Knox, Jim Lanz, Rosa Cole-Rodick, Kevin Rodick, Melody Taress Jones, DeAnn Patton, Steven Patton, Jan Sadowski, Lori Lailthor, Catherine Miller, Laura Yurman, Kathy Oleski, V. Pepore, Eva Wenne.

### **APPROVAL OF MINUTES**

Approval of July 5, 2023 Storm Water Committee minutes. Moved by Ms. Barath, seconded by Mr. Nickell. Vote: Yeas: 3 Nays: 0. **Motion carried.**

### **UNFINISHED BUSINESS**

#### **1. Storm Water/Infrastructure Maintenance Monthly Report**

See report.

#### **2. Maintenance Projects**

Mr. Haselton reported that he has been working with a contractor that will be doing dredging at the Dover Farms Apartments; this is something we have wanted them to do. They are working on where they are going to take the material, which should be happening soon.

#### **3. Turnpike Mitigation**

No update.

#### **4. York Road Property**

Mr. Kelly spoke on the parcel that was subject to eminent domain, whereas we have received the deed. We made two attempts to file the deed and we believe we were successful on the last attempt. However, we are waiting to hear from the Recorder's Office.

#### **5. Cleaning the Mains**

Mr. Smith summarized that we are still in the Timber Ridge development and expect to wrap up before winter.

#### **6. NEORSD projects update**

Mr. Haselton provided an update on the area of Sprague Road and Thornhurst Drive. As we mentioned previously, the culvert replacement is complete. The stream restoration, downstream of that crossing, is also complete. Planting season will begin in October for the Sewer District there. Just downstream of that, on the other side of Thornhurst, we are working on the easements with the residents; we are negotiating.

Regarding the other large project, Valley Lane, they will begin construction. We had a pre-construction meeting two weeks ago with the Sewer District, whereas that contractor is expected to begin in the fall. That will be a longer-term project; more so in Broadview Heights than in North Royalton.

Ms. Barath mentioned that she did visit the basin on the night of the storm. She noted that it was full. She believed that the volume of water was larger than what was in the basin, unfortunately; which is another issue we need to discuss.

### **NEW BUSINESS**

There was none.

### **ADJOURNMENT**

Moved by Ms. Barath, seconded by Mr. Nickell **to adjourn the September 5, 2023 meeting.** Yeas: 3; Nays: 0.  
**Motion carried. Meeting adjourned at 8:32 p.m.**

# Stormwater Jobs

July 2023

Property Address	Work performed	Date
Timber Ridge Dev.	clean storm mains and catch basins	3-Jul
10131 Albion	redefined ditch	5-Jul
8093 Tilby	ditched east of driveway and installed rip rap west of driveway	6-Jul
Jamestown	vac'd out catch basins	6-Jul
10470 Castle	patched infiltration in manhole and filled sinkhole	7-Jul
18019 Bennett	filled sinkhole	7-Jul
6409 Royalwood	storm call, could not locate cleanout	7-Jul
City Hall	vac'd catch basins in parking lot	10-Jul
10720 State	landscaped around apron	10-Jul
8093 Tilby	landscaped around apron	10-Jul
11167 Shawnee Ci	relieved street flooding(silt screen on catch basins)	10-Jul
9940 Dublin	vac'd catch basin	10-Jul
4243 Eagle Pt	tear out and rebuild catch basin	11-Jul
13073 Eagles Landing	rebuilt catch basin	11-Jul
11609 Glen Abbey	landscaped sinkhole	11-Jul
10224 State	tested and filled sinkhole	11-Jul
3220 Foxwood	dye tested low area in yard. No infiltration	11-Jul
9940 Dublin	tear out and rebuild catch basin	12-Jul
12289 Ridge	clean storm mains and catch basins	12-Jul
4243 Eagle Pt	formed for concrete	13-Jul
9940 Dublin	formed for concrete	13-Jul
Timber Ridge Dev.	clean storm mains and catch basins	13-Jul
	flood patrol	13-Jul
4243 Eagle Pt	poured concrete around catch basin	14-Jul
9940 Dublin	poured concrete around catch basin	14-Jul
6162 Akins	culvert replacement-tear out apron, installed pipe and stone	17-Jul
6162 Akins	formed and poured concrete apron	18-Jul
Basin 060	cleared debris	18-Jul
10231 Albion	cleared vegetation from culvert	18-Jul
6162 Akins	saw cut apron	19-Jul
Helen Dr	jack hammered sanitary manhole lid	19-Jul
Timber Ridge Dev.	clean storm mains and catch basins	19-Jul
Heasley Field	set up to install drain tile	19-Jul

# Stormwater Jobs

July 2023

Heasley Field	installed drain tile	20-Jul
Citywide	flood patrol and storm calls	21-Jul
Citywide	flood patrol and storm calls	24-Jul
Citywide	flood patrol and storm calls	25-Jul
Citywide	flood patrol and storm calls	26-Jul
Cady Rd	vac'd debris and leaves out of ditches	27-Jul
Harley Hills	cleaned debris at culvert	27-Jul
W Wallings	vac'd debris and leaves out of ditches	28-Jul
6710 Akins	televised culvert	31-Jul
3060 Rustic	storm call, could not locate cleanout	31-Jul
8253 Claridge Ct	filled sinkhole	31-Jul
7606 Akins	relandscaped-washed out in storm	31-Jul
8638 Dan Dr	vac'd catch basins and jetted storm lateral	31-Jul

# Stormwater Jobs

August 2023

Property Address	Work performed	Date
9221 Albion	redefined ditch	1-Aug
11462 Abbey	redefined ditch	1-Aug
11841 Abbey	cleaned catch inlet	1-Aug
9445 Potomac	cleaned debris from detention basin	1-Aug
6178 Castle	cleaned debris from detention basin	1-Aug
Heasley field	installed drain tile	2-Aug
Fire Station #1	vac and jet storm catch basins	2-Aug
Heasley field	installed drain tile	3-Aug
Heasley field	installed drain tile	4-Aug
7505 James	cleaned catch basin	7-Aug
8861 Edgewood	storm call, checked lateral and main, all clear	7-Aug
12601 State	redefined ditch	8-Aug
10701 Akins	redefined ditch	8-Aug
7505 James	rebuilt catch basin	8-Aug
6621 Queensway	cleared debris in detention basin	8-Aug
Heasley field	installed drain tile(finished) installed 550'	9-Aug
12613 State	jet culvert	9-Aug
4853 Dublin	cleaned debris by culvert inlet	9-Aug
10002 Sweetleaf	sealed pipe and joints in manhole	10-Aug
Heasley field	cleaned work area	10-Aug
6710 Akins	filled sinkhole	10-Aug
11462 Abbey	installed rip rap around storm lateral outlet	10-Aug
5264 Akins	cleaned silt and wood debris within City right of way of the box culvert	11-Aug
7406 Edgerton	replaced storm manhole lid	14-Aug
Royal Akins Development	inspected catch basin for repair	14-Aug
10851 Akins	redefined ditch	15-Aug
13771 Rustic	removed roots from storm main and fallen trees by headwall	15-Aug
James	vac and jet storm catch basin for Service Dept	15-Aug
9175 W Wallings	installed culvert	16-Aug
9175 W Wallings	finished culvert install and landscaped	17-Aug
9947 York	redefined ditch	18-Aug
9921 York	redefined ditch	18-Aug
12942 Ridge	storm call, checked lateral and main, all clear	18-Aug

# Stormwater Jobs

August 2023

18633 Ridge	cleaned dirt left by ditch	18-Aug
4861 Vale	tear out and set up apron	22-Aug
4861 Vale	poured concrete apron	22-Aug
4291 Sir Robert	filled sinkhole	22-Aug
5011 Buttonbush	filled sinkhole	22-Aug
	confined space training	23-Aug
9900 Royalton	jet storm lateral	24-Aug
9639 Vista	tried to jet storm lateral (tee is broken)	24-Aug
11179 Hemptstead	vac catch basins and jet main	24-Aug
Valley Ln	checked catch basins and main	24-Aug
13407 York	cleaned wood debris at culvert headwall	24-Aug
Jamestown detention basin	cleaned debris from detention basin	24-Aug
	flood patrol clean up	24-Aug
	flood patrol clean up	25-Aug
11305 State	rebuilt catch basin	28-Aug
9900 Royalton	jet storm lateral	28-Aug
9636 Vista	jet storm lateral (cannot get under road)	28-Aug
11893 W 130th	redefined ditch	29-Aug
9229 W Wallings	redefined ditch	29-Aug
11046 York	scraped berm to allow water to flow to inlets	29-Aug
8565 Albion	saw cut apron	29-Aug
11305 State	landscaped and vac catch basin	29-Aug
5010 Wiltshire	storm call, checked lateral and main, all clear	29-Aug
8565 Albion	tear out and set up apron and culvert	30-Aug
4650 Wiltshire	storm call, could not locate cleanout	30-Aug
11990 Apollo	cleared debris from headwall	30-Aug
7555 Harley Hills	repaired storm line from Cleveland Water repair	30-Aug
8565 Albion	poured concrete apron	31-Aug
City Garden	removed silt fence from catch basin	31-Aug