

Steep Grant

- 1) Will there be a walk through we can do at each school so we can see the layout of each school?
 - Yes you may request a walk thru.
- 2) Is there already a diagram with how many of each type of strobe, panic buttons, and speakers needed at each school? Or is it up to the vendor to determine what is needed and where?
 - Vendor to determine what is needed.
- 3) What types of Access Control Systems are used at each school?
 - Honeywell I believe
- 4) What is the existing PA type in each school?
 - They Vary by school Telecor, Rauland and Bogen
- 5) What is the existing VOIP phone system at each school?
 - Mitel VOIP
- 6) Are the strobes and speakers ok to be IP based over Ethernet? You asked for a non-Ethernet based panic button. But the rest is not clear. Non Ethernet based products are all being phased out and end of life.
 - Yes ok to be IP based but if additional equipment needed it will be provided by vendor.
- 7) Does the cabling need to be on patch panels? If so, who is providing the patch panels?
 - Yes, yes vendor provided
- 8) Is there a standard on the type of cabling that Water town would like to use?
 - Cat 6 Ethernet
- 9) How many people would you like to text at once during a single emergency?
Will the texts be just to Watertown employees or parents too

TBD