

January 27, 2023
REPLACEMENT OF BRIDGE NO. 04409
WOOLSON STREET OVER STEELE BROOK
STATE PROJECT NO. 9153-4409

ADDENDUM NO. 4

QUESTIONS & ANSWERS

Q1. In stage no. 1 at the west end of the abutment no 1 footing there is a manhole that is approximately 1.5' from the footing and the bottom of the manhole is about 4.5' higher than the bottom of the footing. According to the stage 1 drawing there is no temporary earth retaining system in this area. How is the manhole and/or sewer main to be supported/paid for in this area?

A1. *If, as the site is excavated, the need for a temporary earth retaining system arises in areas not previously identified on the plans, additional temporary earth retaining systems will be paid at the contract unit price bid for the item.*

The Bid Proposal Form has been revised to reflect these changes.

There will be no change in the number of calendar days due to this Addendum.

The foregoing is hereby made a part of the contract.