



TOWN OF
WATERTOWN
WATER AND SEWER AUTHORITY

2022 WATER QUALITY REPORT

PWS ID#: CT1539031 WESTGATE

2022 WATER QUALITY REPORT

PWS ID#: CT1539031 WESTGATE

Dear Valued Customer:

The Watertown Water and Sewer Authority (WSA) is pleased to provide its consumers with this report on the drinking water supplied to its customers in Watertown. The information contained in this report explains where your water comes from, what tests are performed to insure the safety of your water as well as where you can acquire additional information about your water supply. We trust you will find this information both interesting and helpful. We want you to know more about the quality of your drinking water.

WATER SOURCE

Your water source is groundwater pumped by wells, which are located along the Nonnewaug River in Woodbury, (the Hart Well Fields). The Watertown Fire District owns and operates two surface reservoirs: Lockwood Reservoir, which is located in Bethlehem, and Judd Pond, which is located in Watertown. These reservoirs are used to augment the flow of water in the Nonnewaug River to replenish the groundwater removed by the wells, located off of Route 61 (the Hart Well Fields), which are owned and operated by the Watertown Fire District.

The water is then pumped from the Neil Drive pump station to the Bald Hill water storage tank, located off of Neil Drive. From there it is metered thru a water meter pit located on Westgate Road, then distributed thru the Watertown Water and Sewer Authority system to your home.

SUBSTANCES THAT COULD BE IN WATER

As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and in some cases, radioactive material, and pick up substances resulting from the presence of animals or from human activity, including:

- Viruses and bacteria, which may come from septic systems, livestock, or wildlife.
- Salts and metals, which can be natural or may result from storm water runoff and farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, or farming.
- Organic chemicals, which originates from industrial processes, gas stations, storm runoff, and septic system.
- Radioactive substances, which can be naturally occurring.

SOURCE WATER PROTECTION

Source water is untreated water from streams, rivers, lakes, or ground aquifers that is used to supply public drinking water. Preventing drinking water contamination at the source makes good public health sense, good economic sense, and good environmental sense, and good environmental sense. You can be aware of the challenges of keeping drinking water safe and take an active role in protecting drinking water. There are lots of ways that you can get involved in drinking water protection activities to prevent the contamination of the groundwater sources. Dispose properly of household chemicals, help clean up the watershed that is the source of your community's water, and attend public meetings to ensure that the community's need for safe drinking water is considered in making decisions about land use.

For more information on source water protection contact the Environmental Protection Agency (EPA) at: (800) 426-4791 or visit their web site at www.epa.gov/sourcewaterprotection

Educational Information About Lead & Copper: The Water and Sewer Authority believes it is important to provide you with information about the sources of lead and copper in drinking water and the health effects associated with them. The primary source of lead and copper in tap water is household plumbing, and plumbing can vary from house to house within the same neighborhood. For information on the levels of lead and copper detected in your drinking water system, please refer to the table in this water quality report.

What is Lead? - Major sources of lead in drinking water are corrosion of household plumbing systems and erosion of natural deposits. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink water containing lead in excess of the action level over many years could develop kidney problems or high blood pressure.

What is copper? - Major sources of copper in drinking water are corrosion of household plumbing systems, erosion of natural deposits and leaching from wood preservatives. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. Anyone with Wilson's Disease should consult their personal doctor.

If you are concerned about elevated lead or copper levels, you may wish to have your water tested. Running your tap for 30 seconds to two minutes before use will significantly reduce the levels of lead and copper in the water. Additional information is available from the U.S. Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Special Considerations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center of Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline(1-800-426-4791).

CONSERVING WATER INDOORS & OUTDOORS

Conserving water helps to ensure that we have an adequate supply of water for public health and safety, and reduces demands on the state's water resources. The typical residential customer uses 15,000 gallons of water per quarter or 60,000 per year. You can play a role in conserving water by becoming conscious of the amount of water your household is using. Conserving can lower your water bill, and depending on the community where you live, may reduce your sewer bill.

SOME THINGS YOU CAN DO TO CONSERVE:

- **Repair leaking toilets-check for toilet leaks by putting a drop of food coloring in the tank. If the food coloring seeps into the bowl without flushing, there is a leak.**
- **Consider installing a low-flow 1.6 gallon per flush toilet.**
- **Don't use toilets as a wastebasket.**
- **Fix leaking fixtures.**
- **Run full loads in the dishwasher.**
- **Set the water level in the washing machine to match the amount of clothes being washed.**
- **Use mulch around plants and shrubs.**
- **Use a bucket rather than a running hose to wash cars.**

WATER MAIN FLUSHING

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, water quality can deteriorate in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen, disinfectant levels, and an acceptable taste and smell.

During flushing operations in your neighborhood, some short term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use and avoid using hot water, to prevent sediment accumulation in your hot water tank.

Please contact us if you have any questions or if you would like more information on our water main flushing schedule. Our water main flushing schedule is posted on our website: watertownct.org , departments: water and sewer; and will also be advertised in the newspaper.

TOWN OF WATERTOWN WATER & SEWER AUTHORITY TESTING RESULTS || 2022

Inorganic	MCL	MCLG	Highest Detected Level (90 th Percentile)	Range of Detection	Met Drinking Water Standards	Typical Source of Contaminate
Copper (PPM) Tested in 2022	AL 1.3	AL 1.3	0.60	0.02 – 0.98	Yes	Corrosion of household plumbing system
Lead (PPB) Tested in 2022	AL 15	0	0	0	Yes	Corrosion of household plumbing system
Microbiological						
Total Coliform Bacteria Tested in 2022	More than 1	0	Absent	Absent	Yes	Naturally present in the environment
Organic						
TTHMs (PPB) Total Trihalomethanes	80	0	30 Highest Site (LRAA)	30 1 Sample	Yes	By-product of drinking water disinfection
HAAs (PPB) Haloacetic Acids	60	N/A	10 Highest Site (LRAA)	10 1 Sample	Yes	By-product of drinking water disinfection
Chlorine	MRDL 4	MRDLG 4	1.0	0.4 – 1.0	Yes	Water additive used to control microbes

2022 WATER QUALITY REPORT

PWS ID#: CT1539031 WESTGATE

WATER TESTING RESULTS BY THE TOWN OF WATERTOWN FIRE DISTRICT || 2022

Reference: Watertown Fire District 2022 Water Quality Report

REGULATED SUBSTANCES							
SUBSTANCE (UNIT OF MEASURE) (YEAR TESTED)	MCL (MRDL)	MCLG (MRDLG)	AMOUNT DETECTED	RANGE LOW - HIGH	VIOLATION	TYPICAL SOURCE	
Alpha Emitters (pCi/L) (2021)	15	0	-0.649	N/A	No	Erosion of natural deposits	
Asbestos (MFL) (2021)	7	7	ND	N/A	No	Decay of asbestos cement water mains, Erosion of natural deposits	
Barium (PPM) (2022)	2	2	0.0199	N/A	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Chlorine (PPM) (2021)	4	4	1.01	0.75 – 1.22	No	Water additive used to control microbes	
Combined Radium (pCi/L) (2021)	5	0	0.732	0.161 – 0.732	No	Erosion of natural deposits	
Haloacetic Acids (HAAs – Stage 2 (PPB) (2022)	60	N/A	6.83	3.67 – 6.83	No	By-product of drinking water disinfection	
Nitrate (PPM) (2022)	10	10	0.424	N/A	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
TTHMs (Total Trihalomethanes) Stage 2 (PPB) (2022)	80	N/A	11.0	7.91 – 11.0	No	By-product of drinking water disinfection	
Turbidity ¹ (NTU) (2022)	TT	N/A	2.48	ND – 2.48	No	Soil runoff	
Uranium (PPB) (2021)	30	0	<1.02	N/A	No	Erosion of natural deposits	
Tap water samples were collected for Lead and Copper analyses from sites throughout the community							
SUBSTANCE (UNIT OF MEASURE) (YEAR TESTED)	AL	MCLG	HIGHEST DETECTED LEVEL (90 th Percentile)	RANGE LOW - HIGH	SITES ABOVE AL /TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (PPM) (2021)	1.3	1.3	0.493	N/A	0 / 20	No	Corrosion of household plumbing system; Erosion of natural deposits
Lead (PPB) (2021)	15	0	1.81	N/A	0 / 20	No	Corrosion of household plumbing system; Erosion of natural deposits

¹ Turbidity is the measure of the cloudiness of the water. It is monitored because it is a good indicator of water quality and the effectiveness of disinfectants.

TERMS & ABBREVIATIONS

AL = Action Level: The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

LRAA = Locational Running Annual Average: Average of four quarterly results used to evaluate compliance.

MCLG = Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

MCL = Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

MRDL = Maximum Residual Disinfection Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG = Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contamination.

mREM/yr = Millirems per year: A measurement of radiation absorbed by the body.

NL = Notification Level: There is no MCL for sodium, however, the Connecticut DPH requires customers to be notified if sodium exceeds 28 ppm.

NTU = Nephelometric Turbidity Unit: A measure of water clarity.

ppm = Parts per million, or milligrams per liter, mg/l

ppb or ug/L = Parts per billion, or micrograms per liter ug/l

pCi/l = Picocuries per liter: A unit of measure of radioactivity.

TT = Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

N/A = Not Applicable

N/R = Not Regulated

mg/L = Milligrams per liter

ND = Not Detected

SMCL = Secondary Maximum Contaminant Level: is established to regulate aesthetics of drinking water like taste and odor.

QUESTIONS?

For more information about this report, or for any questions relating to your drinking water, please call The Watertown Water & Sewer Authority, at (860) 945-5299, or e-mail at: wsa-info@watertownct.org

Town of Watertown
Water & Sewer Authority
747 French Street
Oakville, CT 06779



TOWN OF
WATERTOWN
WATER AND SEWER AUTHORITY
2022 WATER QUALITY REPORT
PWS ID#: CT1539031-WESTGATE