



**TOWN OF**  
**WATERTOWN**  
**WATER AND SEWER AUTHORITY**

---

**2020 WATER QUALITY REPORT**

PWS ID#: CT1539031 WESTGATE

# 2020 WATER QUALITY REPORT

PWS ID#: CT1539031 WESTGATE

## Dear Valued Customer:

The Watertown Water and Sewer Authority (WSA) is pleased to provide its consumers with this report on the drinking water supplied to its customers in Watertown. The information contained in this report explains where your water comes from, what tests are performed to insure the safety of your water as well as where you can acquire additional information about your water supply. We trust you will find this information both interesting and helpful. We want you to know more about the quality of your drinking water.

## WATER SOURCE

Your water source is groundwater pumped by wells, which are located along the Nonnewaug River in Woodbury, (the Hart Well Fields). The Watertown Fire District owns and operates two surface reservoirs: Lockwood Reservoir, which is located in Bethlehem, and Judd Pond, which is located in Watertown. These reservoirs are used to augment the flow of water in the Nonnewaug River to replenish the groundwater removed by the wells, located off of Route 61 (the Hart Well Fields), which are owned and operated by the Watertown Fire District.

The water is then pumped from the Neil Drive pump station to the Bald Hill water storage tank, located off of Neil Drive. From there it is metered thru a water meter pit located on Westgate Road, then distributed thru the Watertown Water and Sewer Authority system to your home.

## SUBSTANCES THAT COULD BE IN WATER

As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and in some cases, radioactive material, and pick up substances resulting from the presence of animals or from human activity, including:

- Viruses and bacteria, which may come from septic systems, livestock, or wildlife.
- Salts and metals, which can be natural or may result from storm water runoff and farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, or farming.
- Organic chemicals, which originates from industrial processes, gas stations, storm runoff, and septic system.
- Radioactive substances, which can be naturally occurring.

To insure that our sources of supply remain protected, the Waterbury Bureau of Water conducts annual Watershed Sanitary Surveys as well as semi-annual Water Quality and Pollution Source Assessments. This information is available by contacting the Waterbury Bureau of Water at 203-574-8251, also the completed SWAP (Source Water Assessment and Protection) program can be found at: [www.ct.gov/dph/water/SWAP/community/ct1510011.pdf](http://www.ct.gov/dph/water/SWAP/community/ct1510011.pdf). The Shepaug and Wigwam Reservoir systems, surface water and the overall susceptibility to potential contamination is "moderate".

## SOURCE WATER PROTECTION

Source water in untreated water from streams, rivers, lakes, or ground aquifers that is used to supply public drinking water. Preventing drinking water contamination at the source makes good public health sense, good economic sense, and good environmental sense, and good environmental sense. You can be aware of the challenges of keeping drinking water safe and take an active role in protecting drinking water. There are lots of ways that you can get involved in drinking water protection activities to prevent the contamination of the groundwater sources. Dispose properly of household chemicals, help clean up the watershed that is the source of your community's water, and attend public meetings to ensure that the community's need for safe drinking water is considered in making decisions about land use. For more information on source water protection contact the Environmental Protection Agency (EPA) at (800) 426-4791 or visit their web site at [www.epa.gov/sourcewaterprotection](http://www.epa.gov/sourcewaterprotection).

**Educational Information About Lead & Copper:** The Water and Sewer Authority believes it is important to provide you with information about the sources of lead and copper in drinking water and the health effects associated with them. The primary source of lead and copper in tap water is household plumbing, and plumbing can vary from house to house within the same neighborhood. For information on the levels of lead and copper detected in your drinking water system, please refer to the table in this water quality report.

**What is Lead?** - Major sources of lead in drinking water are corrosion of household plumbing systems and erosion of natural deposits. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink water containing lead in excess of the action level over many years could develop kidney problems or high blood pressure.

**What is copper?** - Major sources of copper in drinking water are corrosion of household plumbing systems, erosion of natural deposits and leaching from wood preservatives. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. Anyone with Wilson's Disease should consult their personal doctor.

*If you are concerned about elevated lead or copper levels, you may wish to have your water tested. Running your tap for 30 seconds to two minutes before use will significantly reduce the levels of lead and copper in the water. Additional information is available from the U.S. Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.*

**Special Considerations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center of Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline(1-800-426-4791).

## **WATER MAIN FLUSHING**

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, water quality can deteriorate in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen, disinfectant levels, and an acceptable taste and smell.

During flushing operations in your neighborhood, some short term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use and avoid using hot water, to prevent sediment accumulation in your hot water tank.

Please contact us if you have any questions or if you would like more information on our water main flushing schedule. Our water main flushing schedule is posted on our website: [watertownct.org](http://watertownct.org) , departments: water and sewer; and will also be advertised in the newspaper.

# 2020 WATER QUALITY REPORT

PWS ID#: CT1539031 WESTGATE


## CONSERVING WATER INDOORS & OUTDOORS

Conserving water helps to ensure that we have an adequate supply of water for public health and safety, and reduces demands on the state's water resources. The typical residential customer uses 15,000 gallons of water per quarter or 60,000 per year. You can play a role in conserving water by becoming conscious of the amount of water your household is using. Conserving can lower your water bill, and depending on the community where you live, may reduce your sewer bill.

### SOME THINGS YOU CAN DO TO CONSERVE:

- **Repair leaking toilets-check for toilet leaks by putting a drop of food coloring in the tank. If the food coloring seeps into the bowl without flushing, there is a leak.**
- **Consider installing a low-flow 1.6 gallon per flush toilet.**
- **Don't use toilets as a wastebasket.**
- **Fix leaking fixtures.**
- **Run full loads in the dishwasher.**
- **Set the water level in the washing machine to match the amount of clothes being washed.**
- **Use mulch around plants and shrubs.**
- **Use a bucket rather than a running hose to wash cars.**

### INDOOR HOUSEHOLD WATER USAGE



## TOWN OF WATERTOWN WATER & SEWER AUTHORITY TESTING RESULTS || 2020

Inorganic	MCL	MCLG	Highest Detected Level	Range of Detection	Met Drinking Water Standards	Typical Source of Contaminate
Copper (PPM) Tested in 2018	AL 1.3	AL 1.3	0.74 (90th Percentile)	0.02 - 0.74	Yes	Corrosion of household plumbing system
Lead (PPB) Tested in 2018	AL 15	0	2 (90th Percentile)	1 - 2	Yes	Corrosion of household plumbing system
Microbiological						
Total Coliform Bacteria (2020)	More than 1	0	Absent	Absent	Yes	Naturally present in the environment
Organic (2020)						
TTHMs (PPB) Total Trihalomethanes	80	0	16 Highest Site (LRAA)	16 1 Sample	Yes	By-product of drinking water disinfection
HAAs (PPB) Haloacetic Acids	60	N/A	5 Highest Site (LRAA)	5 1 Sample	Yes	By-product of drinking water disinfection
Chlorine	MRDL 4	MRDLG 4	1.3	0.2 - 1.3	Yes	Water additive used to control microbes

# 2020 WATER QUALITY REPORT

PWS ID#: CT1539031 WESTGATE

## WATER TESTING RESULTS BY THE WATERTOWN FIRE DISTRICT 2020 Reference Watertown Fire District 2020 Water Quality Report

### REGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Alpha Emitters (pCi/L)	2019	15	0	-0.183	NA	No	Erosion of natural deposits
Barium (ppm)	2019	2	2	0.0247	NA	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chlorine (ppm)	2020	[4]	[4]	1.00	0.72–1.40	No	Water additive used to control microbes
Combined Radium (pCi/L)	2019	5	0	0.545	NA	No	Erosion of natural deposits
Haloacetic Acids [HAAs] (ppb)	2020	60	NA	16.4	3.0–16.4	No	By-product of drinking water disinfection
Nitrate (ppm)	2020	10	10	0.476	NA	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
THHMs [Total Trihalomethanes] (ppb)	2020	80	NA	16.1	5.3–16.1	No	By-product of drinking water disinfection
Turbidity <sup>1</sup> (NTU)	2020	TT	NA	1.75	ND–1.75	No	Soil runoff

### Tap Water Samples Collected for Copper and Lead Analyses from Sample Sites throughout the Community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH %ILE)	SITES ABOVE AL/TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2019	1.3	1.3	0.49	0/20	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2019	15	0	3.8	0/20	No	Corrosion of household plumbing systems; Erosion of natural deposits

### SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	MCLG	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Chloride (ppm)	2019	250	NA	28.6	NA	No	Runoff/leaching from natural deposits
Sulfate (ppm)	2019	250	NA	8.19	NA	No	Runoff/leaching from natural deposits; Industrial wastes

### UNREGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Sodium (ppm)	2019	26	NA	Naturally present in the environment (added to adjust pH); Runoff from road salts

<sup>1</sup>Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of water quality and the effectiveness of disinfectants.

### TERMS & ABBREVIATIONS

**AL** = Action Level: The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

**LRAA** = Locational Running Annual Average: Average of four quarterly results used to evaluate compliance.

**MCLG** = Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

**MCL** = Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

**MRDL** = Maximum Residual Disinfection Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG** = Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contamination.

**mREM/yr** = Millirems per year: A measurement of radiation absorbed by the body.

**NL** = Notification Level: There is no MCL for sodium, however, the Connecticut DPH requires customers to be notified if sodium exceeds 28 ppm.

**NTU** = Nephelometric Turbidity Unit: A measure of water clarity.

**ppm** = Parts per million, or milligrams per liter, mg/l

**ppb or ug/L** = Parts per billion, or micrograms per liter ug/l

**pCi/l** = Picocuries per liter: A unit of measure of radioactivity.

**TT** = Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

**N/A** = Not Applicable

**N/R** = Not Regulated

**mg/L** = Milligrams per liter

**ND** = Not Detected

**SMCL** = Secondary Maximum Contaminant Level: is established to regulate aesthetics of drinking water like taste and odor.

Reference is made to the 2019 Annual Water Quality Report by The Watertown Fire District.

### QUESTIONS?

For more information about this report, or for any questions relating to your drinking water, please call The Watertown Water & Sewer Authority, at (860) 945-5299, or e-mail at: [caterino@watertownct.org](mailto:caterino@watertownct.org)



**PUBLIC NOTIFICATION**  
Important Information About Your Drinking Water

**REPORTING VIOLATION**

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.*

Date: 5-17-2021  
PWSID: CT1539031  
To: The Customers/Residents of Watertown Water & Sewer - Westgate  
From: The Watertown Water and Sewer Authority

Our public water system recently violated drinking water reporting requirements. As a supplier of public drinking water, we are required to monitor the water quality of our water supply to insure that it meets the current drinking water standards. Failure to report results of such monitoring to the State Department of Public Health Drinking Water Section constitutes a violation. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We **did not report monitoring results in a timely manner** for the requirement(s) listed below:

Total Coliform (WSF ID: 00600; Monitoring Period: February 1, 2020 - February 29, 2020)

**What is being done?**

The following areas have been affected:  
All of the Westgate system.

The following steps are being taken to correct this violation:

We notified our lab, Regional Water Authority, to re-send the testing results to the DPH with the correct PWSID.

We expect to return to compliance or resolve the situation by 7-1-2020

If you have any questions please contact Vincent Caterino at 860-945-5299 or  
(owner, operator or designee) (date) (phone #)  
by mail at 747 French Street, Oakville, CT, 06779  
(Street) (Town) (State) (Zip Code)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Town of Watertown  
Water & Sewer Authority  
747 French Street  
Oakville, CT 06779



**TOWN OF**  
**WATERTOWN**  
WATER AND SEWER AUTHORITY  
**2020 WATER QUALITY REPORT**

PWS ID#: CT1530021