

Month/Year _____

Cyanuric Acid Level _____ ppm

Date of test: _____

DAILY SWIMMING POOL, SPA or SPRAY GROUND OPERATION RECORD

(This record shall be maintained for at least two years for review by the Environmental Health Department)

FACILITY NAME: _____

OPERATOR: _____

Day	Time	Free Chlorine	pH	Time	Free Chlorine	pH	Chemicals Added (type & amount)	Maintenance (backwash, etc)
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								

Disinfectants in Pools:

Chlorine 1.0 to 10.0 ppm without CYA
2.0 to 10.0 ppm with CYA

pH 7.2 to 7.8 - minimum
7.4 to 7.6 - ideal

Bromine 2.0 ppm minimum

Cyanuric Acid

0 to 100 ppm

Maximum water temperature

104° F

Disinfectants in Spas, Wading Pools & Spray Grounds:

Chlorine 3.0 to 10.0 ppm

Bromine 4.0 ppm minimum