



Record ID: PR0000906

### Inspection Report

<b>Facility Name</b> HUNTER'S LANDING APARTMENTS			<b>Total Violations</b>	0	<b>Date:</b> 08/31/2018	<b>Total Time:</b> 30
<b>Facility Address</b> 1205 E 22ND ST			<b>Total Significant Violations</b>	0	<b>Start:</b> 4:00 pm	<b>Finish:</b> 4:30 pm
<b>City/State</b> MARYSVILLE, CA	<b>Zip Code</b> 95901	<b>Phone</b> (530) 743-5357	<b>Operator Name</b> DYANA HEER		<b>Operator Phone</b> (530) 743-5357	
<b>Program:</b> 0860 - PUBLIC SWIMMING POOL-SPA PERMIT		<b>Service:</b> FOLLOW-UP		<b>Result:</b> MEETS STANDARDS		

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item

Fill in the appropriate box for COS and/or R

**In** = In compliance    **OUT** = Not In compliance    **N/O** = Not observed    **N/A** = Not applicable    **COS** = Corrected on-site during inspection    **R** = Repeat violation

0	Chlorinator	
---	-------------	--

### VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS

Item No	Remarks
	Disinfectant Residual (ppm): 6.5 ppm
	pH: 7.8
	Chlorinator: New chlorinator installed & operational at time of inspection.

**Overall Inspection Comments:**

*Pool okay to open - all previous violations have been corrected.*

<b>Received By</b> JODI BIRD	<b>Title:</b> EH Technician	<b>Date:</b> 8/31/2018
---------------------------------	--------------------------------	---------------------------