



Record ID: PR0002838

**SWIMMING POOL/SPA Inspection Report**

<b>Facility Name</b> LAKE FRANCIS RESORT		<b>Total Violations</b> 11		<b>Date:</b> 06/26/2018	<b>Total Time:</b> 60
<b>Facility Address</b> 13919 LAKE FRANCIS RD		<b>Total Significant Violations</b> 6		<b>Start:</b> 1:30 pm	<b>Finish:</b> 2:30 pm
<b>City/State</b> DOBBINS, CA	<b>Zip Code</b> 95935	<b>Phone</b> (530) 692-1700	<b>Operator Name</b> Rhona Bekker		<b>Operator Phone</b> (530) 692-1700
<b>Program:</b> 0860 - PUBLIC SWIMMING POOL-SPA PERMIT		<b>Service:</b> ROUTINE INSPECTION		<b>Result:</b> MAJOR VIOLATIONS	

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item Fill in the appropriate box for COS and/or R  
**In** = In compliance    **OUT** = Not In compliance    **N/O** = Not observed    **N/A** = Not applicable    **COS** = Corrected on-site during inspection    **R** = Repeat violation

**SWIMMING POOL & SPA**

1	Disinfectant Residual (ppm)	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> COS	<input checked="" type="checkbox"/> MAJ
2	pH	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
3	Cyanuric Acid (ppm)	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ

**RECORD KEEPING**

4	Inadequate Record Keeping	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
5	DPD Test Kit	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

**CLARITY**

6	Poor Clarity	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> COS	<input checked="" type="checkbox"/> MAJ
---	--------------	------------------------------	---	------------------------------	---

**ALGAE**

7	Algae Growth	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ
---	--------------	---	------------------------------	--	------------------------------

**RECIRCULATION EQUIPMENT**

8	Pressure Gauges	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
9	Chlorinator	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
10	Flowmeter	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
11	Filter	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
12	Water Leakage	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
13	Cleanliness of Area	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
14	AB1020 Compliant	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input checked="" type="checkbox"/> MAJ

**SKIMMERS**

15	Retarded Flow	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
16	Weir	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
17	Basket	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
18	Skimmer Cover	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M

**RESCUE & SAFETY EQUIPMENT**

19	Rescue Pole with Crook	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
20	Life Ring with Rope	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
21	Artificial Respiration Procedure Sign	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
22	Warning-No Lifeguard on Duty Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
23	Emergency Phone Number Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
24	Keep Closed Sign on Gate	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
25	"No Diving" Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
26	No Use After Dark Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
27	First Aid Kit	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
28	Maximum Occupancy Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
29	Diarrhea Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
30	Grab Rail and/or Stair Rail Loose	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	

**DECK**

31	Cracks in decking	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT			<input type="checkbox"/> MAJ
32	Obstructions on deck	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

Facility Name		Date:	Page 2 of 5
LAKE FRANCIS RESORT		06/26/2018	
<b>SWIMMING POOL &amp; SPA</b>			
33	Inadequate drainage of pool area	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
<b>BOTTOM DRAIN</b>			
34	Cover Plate VGBA Compliant	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
35	Drain Visible from Deck	<input type="checkbox"/> NVO <input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input checked="" type="checkbox"/> M
<b>POOL FINISH</b>			
36	Cracks in pool shell	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O	<input type="checkbox"/> MAJ
37	Rough areas in pool shell	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O	<input type="checkbox"/> MAJ
<b>DIVING BOARD</b>			
38	Non-slip Surface	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
39	Condition	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
<b>POOL LIGHT</b>			
40	Non-functioning pool light	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
41	Pool Light Separating from Wall	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
<b>TILE</b>			
42	Cracked Tiles	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
43	Dirty Tiles	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
44	Depth Markers	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
<b>CLEANLINESS</b>			
45	Pool Bottom Dirty	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
46	Floating Debris in Pool	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
<b>FENCING</b>			
47	Adequacy of Fencing	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
48	Gates Self-closing	<input type="checkbox"/> NVO <input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input checked="" type="checkbox"/> MAJ
49	Gates are Self-latching	<input type="checkbox"/> NVO <input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input checked="" type="checkbox"/> MAJ
50	One Means of Keyless Egress	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
<b>ANCILLARY FACILITY</b>			
51	Adequacy of Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
52	Poor Sanitation of Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
53	Structural Defect in Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
54	Hot Water Provided in Bathrooms	<input type="checkbox"/> NVO <input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
55	Poor Sanitation of Showers	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
<b>SPA REQUIREMENTS</b>			
56	Spa Temperature	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
57	Spa Pool Warning Signs	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M
58	Spa Thermometer	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M

**VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS**

Item No	Remarks																																								
1	<p>Disinfectant Residual (ppm): Disinfectant Residual - The pool facility did not meet the Maximum requirements for Disinfectant residuals. The facility must have a maximum disinfectant residual below 10.0 ppm to remain open. Correct immediately or closure of the pool shall be required.</p> <p>11.0 ppm during today's inspection</p> <p>CPC § 65529. Public Pool Disinfection            (a) Public pools, when open or in use, shall be disinfected continuously by a chemical that imparts a disinfectant at concentrations consistent with subdivision (b) of this section. If halogens other than chlorine are used, residuals of equivalent strength shall be maintained.</p> <p>(b) The minimum and maximum concentrations of disinfectant residuals in public pool water shall be:</p> <table style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <thead> <tr> <th colspan="2"></th> <th colspan="2" style="text-align: center;">FREE-CHLORINE RESIDUAL</th> <th colspan="2"></th> <th colspan="2"></th> </tr> <tr> <th colspan="2"></th> <th colspan="2" style="text-align: center;">WITHOUT CYA</th> <th colspan="2" style="text-align: center;">WITH CYA</th> <th colspan="2"></th> </tr> <tr> <th colspan="2"></th> <th style="text-align: center;">MIN</th> <th style="text-align: center;">MAX</th> <th style="text-align: center;">MIN</th> <th style="text-align: center;">MAX</th> <th style="text-align: center;">MIN</th> <th style="text-align: center;">MAX</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">PUBLIC POOLS*</td> <td></td> <td style="text-align: center;">1.0 PPM</td> <td style="text-align: center;">10.0 PPM</td> <td style="text-align: center;">2.0 PPM</td> <td style="text-align: center;">10.0 PPM</td> <td style="text-align: center;">2.0 PPM</td> <td></td> </tr> <tr> <td style="text-align: center;">SPAS, WADING, &amp; SPRAY GROUNDS:</td> <td></td> <td style="text-align: center;">3.0 PPM</td> <td style="text-align: center;">10.0 PPM</td> <td style="text-align: center;">3.0 PPM</td> <td style="text-align: center;">10.0 PPM</td> <td style="text-align: center;">4.0 PPM</td> <td></td> </tr> </tbody> </table> <p>---            BROMINE RESIDUAL</p> <p>CYA = cyanuric acid. Min = minimum, Max = maximum, ppm = parts per million            *This includes all public pools except spas, wading pools, and spray grounds.</p>			FREE-CHLORINE RESIDUAL								WITHOUT CYA		WITH CYA						MIN	MAX	MIN	MAX	MIN	MAX	PUBLIC POOLS*		1.0 PPM	10.0 PPM	2.0 PPM	10.0 PPM	2.0 PPM		SPAS, WADING, & SPRAY GROUNDS:		3.0 PPM	10.0 PPM	3.0 PPM	10.0 PPM	4.0 PPM	
		FREE-CHLORINE RESIDUAL																																							
		WITHOUT CYA		WITH CYA																																					
		MIN	MAX	MIN	MAX	MIN	MAX																																		
PUBLIC POOLS*		1.0 PPM	10.0 PPM	2.0 PPM	10.0 PPM	2.0 PPM																																			
SPAS, WADING, & SPRAY GROUNDS:		3.0 PPM	10.0 PPM	3.0 PPM	10.0 PPM	4.0 PPM																																			
2	pH: 7.4																																								
3	Cyanuric Acid (ppm): 60 ppm																																								
6	<p>Poor Clarity: The water clarity of the pool facility was observed with poor visibility, and the bottom of the pool at the maximum depth is barely visible. The facility must maintain adequate clarity and visibility of the pool facility water at the maximum depth of the pool. Immediate Closure of the pool facility is required. Approval to re-open the pool facility must be made in writing by Environmental Health.</p> <p>CPC § 65527. Water Clarity:</p> <p>The public operator shall maintain clear pool water while the public pool is in use. The pool operator shall close the public pool if the bottom of the pool at the maximum depth is not clearly visible from the deck. The pool operator shall not reopen the public pool for use until the pool water is clean and clear, and the bottom of the pool at the maximum depth is clearly visible from the deck. If the bottom of the pool is not visible 48 hours following inspection and closure by the enforcing agent, the enforcing agent may order the pool drained.</p> <p>§ 65533. Public Pool Cleanliness.</p> <p>(a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash or leaves to accumulate in the public pool. The pool operator shall ensure that water levels shall be maintained and operated to remove such material continuously through the pool skimming system in accordance with Section 3136B, Title 24, California Building Code.</p> <p>(b) The pool operator shall clean the bottom, sides and other surfaces of the public pool as often as necessary to keep the bottom, sides and public pool surfaces clean and free of slime and algae.</p>																																								
10	Flowmeter: One of the filter systems was not operating or was operating at a VERY low flow rate. This could be contributing to the poor clarity of the pool water.																																								
12	Water Leakage: Significant amount of water next to one of the filters.																																								
14	AB1020 Compliant: Please provide YCEH with the maintenance records for the 2 Vac-alert systems.																																								

Facility Name LAKE FRANCIS RESORT	Date: 06/26/2018	Page 4 of 5
16	<p>Weir: The skimmer weir equipment is missing/broken. The pool facility shall maintain pool equipment and repair/replace broken or missing skimmer weir equipment. Correct within 7 days.</p> <p>3136B.1 Surface skimmers. Each surface skimmer shall comply with the following provisions:</p> <ol style="list-style-type: none"> <li>1. The skimmer shall be recessed into the pool wall; and</li> <li>2. The skimmer shall be individually adjustable for the rate of flow with either an external or internal device; and</li> <li>3. If used, a skimmer equalizer suction outlet located on the pool wall shall be connected to at least two suction grate assemblies that meet the ASME/ANSI A112.19.8 performance standard and located at least 3 feet (915 mm) apart in any dimension between the drains; and</li> <li>4. The skimmer weir shall automatically adjust to variations in the pool water level over a range of not less than 4 inches (102 mm); and</li> <li>5. The skimmer shall be provided with an air lock protective device which shall not permit leakage of air into the recirculation suction piping system. This device shall not leak more than 3 GPM (11.356 L/m) of water during normal operations; and</li> <li>6. Each skimmer shall be provided with a removable and cleanable screen or basket to trap objects. The screen or basket shall be accessible through an opening in the deck above the skimmer; and</li> <li>7. There shall be a minimum of one skimmer for every 500 square feet or less of pool water surface area or an adequate number to meet 100 percent of pump flow at the manufacturer's maximum flow rating, whichever is greater; and</li> <li>8. Each skimmer shall be located in relation to pool inlets to aid recirculation and surface skimming; and</li> <li>9. All surface skimmers shall comply with applicable requirements established by the NSF/ANSI 50-2010 performance standard effective August 2010.</li> </ol>	
21	<p>Artificial Respiration Procedure Sign: Sides of notice are curling up &amp; it is difficult to read the instructions.</p>	
35	<p>Drain Visible from Deck: Pool water was very cloudy. The drain covers were barely visible from the deck.</p>	
48	<p>Gates Self-closing: The facility was observed with a gate(s) that do not self-close. The facility shall have all gates that self-close. Closure of pool facility until repaired/replaced and approved by the Health Officer.</p> <p>3119B.2 Gates. Gates and doors opening into the pool enclosure also shall meet the following specifications:</p> <ol style="list-style-type: none"> <li>1. Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Hand activated door or gate opening hardware shall be located at a height no lower than 42 inches (1067 mm) but no higher than 44 inches (1179 mm) above the deck or walkway; and</li> <li>2. Gates and doors shall be capable of being locked during times when the pool is closed. Exit doors which comply with Chapter 10, Title 24, California Code of Regulations shall be considered as meeting these requirements; and</li> <li>3. The pool enclosure shall have at least one means of egress without a key for emergency purposes. Unless all gates or doors are so equipped, those gates and/or doors which will allow egress without a key shall have a sign in letters at least 4 inches (102 mm) high stating EMERGENCY EXIT; and</li> <li>4. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.</li> </ol>	
49	<p>Gates are Self-latching: The facility was observed with a gate(s) that do not self-latch. The facility shall have all gates that self-latch. Closure of pool facility until repaired/replaced and approved by the Health Officer.</p> <p>3119B.2 Gates. Gates and doors opening into the pool enclosure also shall meet the following specifications:</p> <ol style="list-style-type: none"> <li>1. Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Hand activated door or gate opening hardware shall be located at a height no lower than 42 inches (1067 mm) but no higher than 44 inches (1179 mm) above the deck or walkway; and</li> <li>2. Gates and doors shall be capable of being locked during times when the pool is closed. Exit doors which comply with Chapter 10, Title 24, California Code of Regulations shall be considered as meeting these requirements; and</li> <li>3. The pool enclosure shall have at least one means of egress without a key for emergency purposes. Unless all gates or doors are so equipped, those gates and/or doors which will allow egress without a key shall have a sign in letters at least 4 inches (102 mm) high stating EMERGENCY EXIT; and</li> <li>4. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.</li> </ol>	

<b>Facility Name</b> LAKE FRANCIS RESORT	<b>Date:</b> 06/26/2018	<b>Page 5 of 5</b>
54	<p>Hot Water Provided in Bathrooms: The facility was observed without hot water in the bathroom(s). The facility shall maintain hot water in the pool facility bathroom(s). Correct within 30 days.</p> <p>ANCILLARY FACILITIES</p> <p>SECTION 3116B DRESSING, SHOWER AND TOILET FACILITIES</p> <p>3116B.4 Water supply.</p> <p>3116.B.4.1 Showers and lavatories shall be provided with hot and cold water faucets.</p> <p>3116B.4.2 Tempered water shall be permitted in lieu of individual hot and cold water faucets.</p> <p>3116B.4.3 A means to limit the hot water to 110°F (61°C) maximum shall be provided to prevent scalding. This temperature limit control shall not be adjustable by the bather.</p>	
<p><b>Overall Inspection Comments:</b></p> <p><i>Pool is hereby closed for use by the Yuba County Environmental Health Department. The pool shall remain closed &amp; locked until inspected and approval for re-opening is given in writing by the Department.</i></p>		
<b>Received By</b>	<b>Title:</b>	<b>Date:</b> 6/26/2018
<b>Inspector</b> JODI BIRD	<b>Title:</b> EH Technician	<b>Date:</b> 6/26/2018