



Yuba County Environmental Health
915 8th Street Suite 123
Marysville, CA 95901
(530) 749-5450

Record ID: PR0000891

Inspection Report

| | | | | | |
|---|--------------------------|--|--|-----------------------------------|---|
| Facility Name LAKE OF THE SPRINGS | | Total Violations 0 | | Date: 06/27/2018 | Total Time: 45 |
| Facility Address 14152 FRENCHTOWN RD | | Total Significant Violations 0 | | Start: 3:00 pm | Finish: 3:45 pm |
| City/State OREGON HOUSE, CA | Zip Code 95962 | Phone (530) 692-1643 | Operator Name RENEE SUNNAFRANK | | Operator Phone (530) 692-1643 |
| Program: 0860 - PUBLIC SWIMMING POOL-SPA PERMIT | | Service: FOLLOW-UP | | Result: MEETS STANDARDS | |

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item

Fill in the appropriate box for COS and/or R

In = In compliance **OUT** = Not In compliance **N/O** = Not observed **N/A** = Not applicable **COS** = Corrected on-site during inspection **R** = Repeat violation

| | | |
|---|-----------------------------|--|
| 0 | Disinfectant Residual (ppm) | |
|---|-----------------------------|--|

VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS

| Item No | Remarks |
|---------|---|
| | Disinfectant Residual (ppm): 6.0 ppm |
| | pH: 7.2 |
| | Cyanuric Acid (ppm): CYA was measured at 90 ppm today. Please add as much fresh water as possible to reduce the amount of CYA in the pool. If the CYA is above 100 ppm, the pool will have to close, be drained and then re-filled. |

Overall Inspection Comments:

Pool has adequate levels of disinfectant.

Inspection of the beach area revealed that the life ring is missing. When the beach is open for use, a life ring must be available at all times. The Lifeboat, oars, rope, and life jackets were all present and in good condition.

| | | |
|---------------------------------|--------------------------------|---------------------------|
| Received By JODI BIRD | Title: EH Technician | Date: 6/27/2018 |
|---------------------------------|--------------------------------|---------------------------|