



Record ID: PR0000893

Inspection Report

Facility Name MALVERN APARTMENTS		Total Violations		2	Date: 09/06/2018	Total Time: 30
Facility Address 1485 N BEALE RD		Total Significant Violations		0	Start: 1:00 pm	Finish: 1:30 pm
City/State EAST LINDA, CA	Zip Code 95901	Phone (530) 743-5700	Operator Name SONDRA MORA		Operator Phone (530) 743-5700	
Program: 0860 - PUBLIC SWIMMING POOL-SPA PERMIT		Service: FOLLOW-UP		Result: MEETS STANDARDS		

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item

Fill in the appropriate box for COS and/or R

In = In compliance **OUT** = Not In compliance **N/O** = Not observed **N/A** = Not applicable **COS** = Corrected on-site during inspection **R** = Repeat violation

0	Cyanuric Acid (ppm)	
---	---------------------	--

VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS

Item No	Remarks
	Disinfectant Residual (ppm): 2.5 ppm
	Spoke with Steve at Bi-County Pools - they turned the chlorinator to a timed dose (set between 1-2 on dial) rather than continuous dosage to alleviate excessive amounts of chlorine in the pool.
	pH: 7.4
	Cyanuric Acid (ppm): 35 ppm
	DPD Test Kit: New test kit that is capable of reading above 5.0 ppm must be on-site and in use within 15 days.
	Chlorinator: Chlorinator has been adjusted and is no longer pumping excessive amount of chlorine into pool.
	Cracked Tiles: Bi-County Pools will fix cracked/missing tiles before pool opens next season.

Overall Inspection Comments:

Pool okay to open.

Received By JODI BIRD	Title: EH Technician	Date: 9/6/2018
Inspector JODI BIRD	Title: EH Technician	Date: 9/6/2018