



Record ID: PR0000873

### SWIMMING POOL/SPA Inspection Report

<b>Facility Name</b> MEADOW WOOD		<b>Total Violations</b> 8		<b>Date:</b> 05/31/2018	<b>Total Time:</b> 60
<b>Facility Address</b> 1210 E 22ND ST		<b>Total Significant Violations</b> 0		<b>Start:</b> 9:30 am	<b>Finish:</b> 10:30 am
<b>City/State</b> MARYSVILLE, CA	<b>Zip Code</b> 95901	<b>Phone</b> (510) 918-5128	<b>Operator Name</b> JOSIE PEREZ		<b>Operator Phone</b> (530) 743-7653
<b>Program:</b> 0860 - PUBLIC SWIMMING POOL-SPA PERMIT		<b>Service:</b> FOLLOW-UP		<b>Result:</b> FAILED TO MEET STANDARDS	

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item Fill in the appropriate box for COS and/or R

**In** = In compliance    **OUT** = Not In compliance    **N/O** = Not observed    **N/A** = Not applicable    **COS** = Corrected on-site during inspection    **R** = Repeat violation

#### SWIMMING POOL & SPA

1	Disinfectant Residual (ppm)	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
2	pH	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
3	Cyanuric Acid (ppm)	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ

#### RECORD KEEPING

4	Inadequate Record Keeping	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
5	DPD Test Kit	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

#### CLARITY

6	Poor Clarity	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
---	--------------	-----------------------------------------	------------------------------	--	------------------------------	------------------------------

#### ALGAE

7	Algae Growth	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT			<input type="checkbox"/> MAJ
---	--------------	-----------------------------------------	------------------------------	--	--	------------------------------

#### RECIRCULATION EQUIPMENT

8	Pressure Gauges	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
9	Chlorinator	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
10	Flowmeter	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
11	Filter	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
12	Water Leakage	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
13	Cleanliness of Area	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
14	AB1020 Compliant	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

#### SKIMMERS

15	Retarded Flow	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
16	Weir	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
17	Basket	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
18	Skimmer Cover	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M

#### RESCUE & SAFETY EQUIPMENT

19	Rescue Pole with Crook	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
20	Life Ring with Rope	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
21	Artificial Respiration Procedure Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
22	Warning-No Lifeguard on Duty Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
23	Emergency Phone Number Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
24	Keep Closed Sign on Gate	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
25	"No Diving" Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
26	No Use After Dark Sign	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
27	First Aid Kit	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
28	Maximum Occupancy Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
29	Diarrhea Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
30	Grab Rail and/or Stair Rail Loose	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	

#### DECK

31	Cracks in decking	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT			<input type="checkbox"/> MAJ
32	Obstructions on deck	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

Facility Name MEADOW WOOD		Date: 05/31/2018	Page 2 of 3
<b>SWIMMING POOL &amp; SPA</b>			
33	Inadequate drainage of pool area	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
<b>BOTTOM DRAIN</b>			
34	Cover Plate VGBA Compliant	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
35	Drain Visible from Deck	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M
<b>POOL FINISH</b>			
36	Cracks in pool shell	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O	<input type="checkbox"/> MAJ
37	Rough areas in pool shell	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O	<input type="checkbox"/> MAJ
<b>DIVING BOARD</b>			
38	Non-slip Surface	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
39	Condition	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
<b>POOL LIGHT</b>			
40	Non-functioning pool light	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
41	Pool Light Separating from Wall	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
<b>TILE</b>			
42	Cracked Tiles	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
43	Dirty Tiles	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
44	Depth Markers	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
<b>CLEANLINESS</b>			
45	Pool Bottom Dirty	<input type="checkbox"/> NVO <input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
46	Floating Debris in Pool	<input type="checkbox"/> NVO <input checked="" type="checkbox"/> OUT <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
<b>FENCING</b>			
47	Adequacy of Fencing	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
48	Gates Self-closing	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
49	Gates are Self-latching	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
50	One Means of Keyless Egress	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
<b>ANCILLARY FACILITY</b>			
51	Adequacy of Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
52	Poor Sanitation of Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
53	Structural Defect in Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
54	Hot Water Provided in Bathrooms	<input type="checkbox"/> NVO <input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
55	Poor Sanitation of Showers	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
<b>SPA REQUIREMENTS</b>			
56	Spa Temperature	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
57	Spa Pool Warning Signs	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M
58	Spa Thermometer	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M

Facility Name MEADOW WOOD		Date: 05/31/2018	Page 3 of 3
<b>VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS</b>			
Item No	Remarks		
1	Disinfectant Residual (ppm): 3.5 ppm		
2	pH: 7.3		
3	Cyanuric Acid (ppm): 50		
9	<p>Chlorinator: The pool facility was observed without an adequate disinfectant chemical feeder. The facility must maintain an automatic chemical feeder. Correct within 30 days or Closure of the pool facility shall be required.</p> <p>CBC § 3133B CHEMICAL FEEDERS:</p> <p>&gt; All chemical feeders including disinfectant feeders and the auxiliary feeders used for solutions, slurries or solids, along with components such as pumps, strainers, tubing connections, tanks and injection fittings shall comply with the provisions of this section.</p> <p>3133B.1 General design requirements. The chemical feeder equipment shall:</p> <ol style="list-style-type: none"> <li>1. Be maintained and repaired according to manufacturers' specifications;</li> <li>2. Be constructed with an adjustable output rate device to permit repeated adjustments without loss of output rate accuracy and adjusted by an automatic chemical monitoring and control system; and</li> <li>3. Meet the applicable requirements established by the NSF/ANSI 50-2010 performance standard effective August 2010.</li> </ol>		
17	Basket: Empty baskets prior to opening.		
20	Life Ring with Rope: Rope is deteriorated on life ring. replace within 30 days.		
31	Cracks in decking: Repairs currently in progress. submit pictures of completed repairs.		
45	<p>Pool Bottom Dirty: The pool facility was observed with dirt, scum, and debris within the pool. The facility shall maintain the water and the premises free of dirt, scum, and debris. Correct within 7 days.</p> <p>§ 65533. Public Pool Cleanliness.</p> <p>(a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash or leaves to accumulate in the public pool. The pool operator shall ensure that water levels shall be maintained and operated to remove such material continuously through the pool skimming system in accordance with Section 3136B, Title 24, California Building Code.</p> <p>(b) The pool operator shall clean the bottom, sides and other surfaces of the public pool as often as necessary to keep the bottom, sides and public pool surfaces clean and free of slime and algae.</p>		
54	<p>Hot Water Provided in Bathrooms: The facility was observed without hot water in the bathroom(s). The facility shall maintain hot water in the pool facility bathroom(s). Correct within 30 days.</p> <p>ANCILLARY FACILITIES</p> <p>SECTION 3116B DRESSING, SHOWER AND TOILET FACILITIES</p> <p>3116B.4 Water supply.</p> <p>3116.B.4.1 Showers and lavatories shall be provided with hot and cold water faucets.</p> <p>3116B.4.2 Tempered water shall be permitted in lieu of individual hot and cold water faucets.</p> <p>3116B.4.3 A means to limit the hot water to 110°F (61°C) maximum shall be provided to prevent scalding. This temperature limit control shall not be adjustable by the bather.</p>		
<p><b>Overall Inspection Comments:</b></p> <p><i>Pool to remain closed until deck work complete &amp; the chlorinator is operational. All other violations must be completed as indicated in the report.</i></p>			
Received By		Title:	Date: 5/31/2018
Inspector JODI BIRD		Title: EH Technician	Date: 5/31/2018