



Record ID: PR0000873

SWIMMING POOL/SPA Inspection Report

Facility Name MEADOW WOOD		Total Violations 7		Date: 08/15/2018	Total Time: 30
Facility Address 1210 E 22ND ST		Total Significant Violations 2		Start: 11:30 am	Finish: 12:00 pm
City/State MARYSVILLE, CA	Zip Code 95901	Phone (510) 918-5128	Operator Name JOSIE PEREZ		Operator Phone (530) 743-7653
Program: 0860 - PUBLIC SWIMMING POOL-SPA PERMIT		Service: ROUTINE INSPECTION		Result: MINOR VIOLATIONS	

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item Fill in the appropriate box for COS and/or R

In = In compliance **OUT** = Not In compliance **N/O** = Not observed **N/A** = Not applicable **COS** = Corrected on-site during inspection **R** = Repeat violation

SWIMMING POOL & SPA

1	Disinfectant Residual (ppm)	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
2	pH	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
3	Cyanuric Acid (ppm)	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ

RECORD KEEPING

4	Inadequate Record Keeping	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
5	DPD Test Kit	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

CLARITY

6	Poor Clarity	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
---	--------------	---	------------------------------	------------------------------	------------------------------

ALGAE

7	Algae Growth	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ
---	--------------	---	------------------------------	--	------------------------------

RECIRCULATION EQUIPMENT

8	Pressure Gauges	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
9	Chlorinator	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
10	Flowmeter	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
11	Filter	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
12	Water Leakage	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
13	Cleanliness of Area	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
14	AB1020 Compliant	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input checked="" type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

SKIMMERS

15	Retarded Flow	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
16	Weir	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
17	Basket	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
18	Skimmer Cover	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M

RESCUE & SAFETY EQUIPMENT

19	Rescue Pole with Crook	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
20	Life Ring with Rope	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
21	Artificial Respiration Procedure Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
22	Warning-No Lifeguard on Duty Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
23	Emergency Phone Number Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
24	Keep Closed Sign on Gate	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
25	"No Diving" Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
26	No Use After Dark Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
27	First Aid Kit	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
28	Maximum Occupancy Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
29	Diarrhea Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
30	Grab Rail and/or Stair Rail Loose	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	

DECK

31	Cracks in decking	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT		<input type="checkbox"/> MAJ
32	Obstructions on deck	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
33	Inadequate drainage of pool area	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ

Facility Name MEADOW WOOD		Date: 08/15/2018	Page 2 of 4	
SWIMMING POOL & SPA				
BOTTOM DRAIN				
34	Cover Plate VGBA Compliant	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
35	Drain Visible from Deck	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M
POOL FINISH				
36	Cracks in pool shell	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/O	<input type="checkbox"/> MAJ
37	Rough areas in pool shell	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/O	<input type="checkbox"/> MAJ
DIVING BOARD				
38	Non-slip Surface	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
39	Condition	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
POOL LIGHT				
40	Non-functioning pool light	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
41	Pool Light Separating from Wall	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
TILE				
42	Cracked Tiles	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
43	Dirty Tiles	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
44	Depth Markers	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
CLEANLINESS				
45	Pool Bottom Dirty	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
46	Floating Debris in Pool	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
FENCING				
47	Adequacy of Fencing	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input type="checkbox"/> MAJ
48	Gates Self-closing	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input checked="" type="checkbox"/> MAJ
49	Gates are Self-latching	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS	<input checked="" type="checkbox"/> MAJ
50	One Means of Keyless Egress	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> MAJ
ANCILLARY FACILITY				
51	Adequacy of Bathrooms	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
52	Poor Sanitation of Bathrooms	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
53	Structural Defect in Bathrooms	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
54	Hot Water Provided in Bathrooms	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
55	Poor Sanitation of Showers	<input type="checkbox"/> NVO	<input checked="" type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O	<input type="checkbox"/> M
SPA REQUIREMENTS				
56	Spa Temperature	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> M
57	Spa Pool Warning Signs	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M
58	Spa Thermometer	<input type="checkbox"/> NVO	<input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R	<input type="checkbox"/> COS <input type="checkbox"/> M

Facility Name MEADOW WOOD		Date: 08/15/2018	Page 3 of 4
VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS			
Item No	Remarks		
1	Disinfectant Residual (ppm): 1.0 ppm		
2	pH: 7.6		
3	Cyanuric Acid (ppm): 0 ppm		
31	Cracks in decking: Repairs done in May 2018 are not adequate. All of the wood that was embedded in the deck was removed and only a portion of the hole that was left has been filled with cement. (see pictures)		
35	Drain Visible from Deck: Drain was caked with debris		
45	<p>Pool Bottom Dirty: The pool facility was observed with dirt, scum, and debris within the pool. The facility shall maintain the water and the premises free of dirt, scum, and debris. Correct within 7 days.</p> <p>§ 65533. Public Pool Cleanliness. (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash or leaves to accumulate in the public pool. The pool operator shall ensure that water levels shall be maintained and operated to remove such material continuously through the pool skimming system in accordance with Section 3136B, Title 24, California Building Code. (b) The pool operator shall clean the bottom, sides and other surfaces of the public pool as often as necessary to keep the bottom, sides and public pool surfaces clean and free of slime and algae.</p>		
46	<p>Floating Debris in Pool: The pool facility was observed with dirt, scum, and debris floating on the surface. The facility shall maintain the water free of dirt, scum, and debris. Correct within 7 days.</p> <p>§ 65533. Public Pool Cleanliness. (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash or leaves to accumulate in the public pool. The pool operator shall ensure that water levels shall be maintained and operated to remove such material continuously through the pool skimming system in accordance with Section 3136B, Title 24, California Building Code. (b) The pool operator shall clean the bottom, sides and other surfaces of the public pool as often as necessary to keep the bottom, sides and public pool surfaces clean and free of slime and algae.</p>		
48	Gates Self-closing: Gate was open when inspectors arrived.		
49	Gates are Self-latching: Gate was open		
51	<p>Adequacy of Bathrooms: The facility was observed to only have one bathroom available for bathers.</p> <p>Section 3116B.2.2 Toilets. Separate toilet facilities shall be provided for each sex.</p> <p>Correct prior to opening next season.</p>		

Facility Name MEADOW WOOD	Date: 08/15/2018	Page 4 of 4
55	<p>Poor Sanitation of Showers: The shower fixtures have been removed and the openings covered with plastic disks. The facility shall maintain/construct/provide sanitary showers for patrons. Correct within 30 days.</p> <p>ANCILLARY FACILITIES SECTION 3116B DRESSING, SHOWER AND TOILET FACILITIES 3116B.1 Shower and dressing facilities shall be provided for users of a pool. Exceptions: 1. Shower and dressing facilities may not be required when bathers have access to such facilities in adjacent living quarters. 2. Public toilet facilities may be omitted when bathers have access to toilet facilities either in living quarters located not more than 300 feet (91,440 mm) in travel distance from the pool, or in an adjacent building such as a recreational facility, clubhouse or cabana.</p> <p>3116B.2.1 Showers. One shower shall be provided for every 50 bathers.</p> <p>3116B.3 Construction. 3116B.3.1 Floors. Floors shall have a hard, nonabsorbent surface, such as Portland cement concrete, ceramic tile or other approved material, which extends upwards onto the wall at least 5 inches (127 mm) with a coved base. Floors which may be walked on by a wet bather shall be slip resistant. Floors shall be sloped not less than 1/4 inch (6.4mm) per foot to floor drains or other approved surface water disposal areas. Carpeting and other similar artificial floor covering shall not be permitted on shower and toilet room floors.</p> <p>Note: Rough rotary, raised rubber or wood float finish of concrete usually provides a slip-resistant finish.</p> <p>3116B.4 Water supply. 3116.B.4.1 Showers and lavatories shall be provided with hot and cold water faucets.</p>	
<p>Overall Inspection Comments: <i>Once violations have been corrected, please contact YCEH to schedule a re-inspection.</i></p>		
Received By	Title:	Date: 8/15/2018
Inspector JODI BIRD	Title: EH Technician	Date: 8/15/2018