



Record ID: PR0004155

### SWIMMING POOL/SPA Inspection Report

<b>Facility Name</b> THE GROVE APARTMENTS		<b>Total Violations</b> 0		<b>Date:</b> 08/30/2018	<b>Total Time:</b> 60
<b>Facility Address</b> 1491 HAMMNTN-SMRTVLL RD		<b>Total Significant Violations</b> 0		<b>Start:</b> 10:30 am	<b>Finish:</b> 11:30 am
<b>City/State</b> MARYSVILLE, CA	<b>Zip Code</b> 95901	<b>Phone</b> (530) 763-4700	<b>Operator Name</b> April Mua		<b>Operator Phone</b> (530) 763-4700
<b>Program:</b> 0860 - PUBLIC SWIMMING POOL-SPA PERMIT		<b>Service:</b> FOLLOW-UP		<b>Result:</b> MEETS STANDARDS	

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item Fill in the appropriate box for COS and/or R

**In** = In compliance    **OUT** = Not In compliance    **N/O** = Not observed    **N/A** = Not applicable    **COS** = Corrected on-site during inspection    **R** = Repeat violation

#### SWIMMING POOL & SPA

1	Disinfectant Residual (ppm)	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
2	pH	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
3	Cyanuric Acid (ppm)	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ

#### RECORD KEEPING

4	Inadequate Record Keeping	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
5	DPD Test Kit	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

#### CLARITY

6	Poor Clarity	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
---	--------------	---	------------------------------	------------------------------	------------------------------

#### ALGAE

7	Algae Growth	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ
---	--------------	---	------------------------------	--	------------------------------

#### RECIRCULATION EQUIPMENT

8	Pressure Gauges	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
9	Chlorinator	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
10	Flowmeter	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
11	Filter	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
12	Water Leakage	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
13	Cleanliness of Area	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
14	AB1020 Compliant	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ

#### SKIMMERS

15	Retarded Flow	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
16	Weir	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
17	Basket	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
18	Skimmer Cover	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M

#### RESCUE & SAFETY EQUIPMENT

19	Rescue Pole with Crook	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
20	Life Ring with Rope	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
21	Artificial Respiration Procedure Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
22	Warning-No Lifeguard on Duty Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
23	Emergency Phone Number Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
24	Keep Closed Sign on Gate	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
25	"No Diving" Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
26	No Use After Dark Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/A	<input type="checkbox"/> R	<input type="checkbox"/> COS	<input type="checkbox"/> M
27	First Aid Kit	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
28	Maximum Occupancy Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
29	Diarrhea Sign	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	
30	Grab Rail and/or Stair Rail Loose	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> N/O	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ	

#### DECK

31	Cracks in decking	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ
32	Obstructions on deck	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT	<input type="checkbox"/> COS	<input type="checkbox"/> MAJ
33	Inadequate drainage of pool area	<input checked="" type="checkbox"/> NVO	<input type="checkbox"/> OUT		<input type="checkbox"/> MAJ

Facility Name THE GROVE APARTMENTS		Date: 08/30/2018	Page 2 of 2
<b>SWIMMING POOL &amp; SPA</b>			
<b>BOTTOM DRAIN</b>			
34	Cover Plate VGBA Compliant	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> MAJ	
35	Drain Visible from Deck	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> COS <input type="checkbox"/> M	
<b>POOL FINISH</b>			
36	Cracks in pool shell	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> MAJ	
37	Rough areas in pool shell	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> MAJ	
<b>DIVING BOARD</b>			
38	Non-slip Surface	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> M	
39	Condition	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> M	
<b>POOL LIGHT</b>			
40	Non-functioning pool light	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O <input type="checkbox"/> M	
41	Pool Light Separating from Wall	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O <input type="checkbox"/> M	
<b>TILE</b>			
42	Cracked Tiles	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS <input type="checkbox"/> MAJ	
43	Dirty Tiles	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS <input type="checkbox"/> MAJ	
44	Depth Markers	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> M	
<b>CLEANLINESS</b>			
45	Pool Bottom Dirty	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS <input type="checkbox"/> MAJ	
46	Floating Debris in Pool	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> COS <input type="checkbox"/> MAJ	
<b>FENCING</b>			
47	Adequacy of Fencing	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS <input type="checkbox"/> MAJ	
48	Gates Self-closing	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS <input type="checkbox"/> MAJ	
49	Gates are Self-latching	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/O <input type="checkbox"/> COS <input type="checkbox"/> MAJ	
50	One Means of Keyless Egress	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> MAJ	
<b>ANCILLARY FACILITY</b>			
51	Adequacy of Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O <input type="checkbox"/> M	
52	Poor Sanitation of Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O <input type="checkbox"/> M	
53	Structural Defect in Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O <input type="checkbox"/> M	
54	Hot Water Provided in Bathrooms	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O <input type="checkbox"/> M	
55	Poor Sanitation of Showers	<input checked="" type="checkbox"/> NVO <input type="checkbox"/> OUT <input type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> N/O <input type="checkbox"/> M	
<b>SPA REQUIREMENTS</b>			
56	Spa Temperature	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> M	
57	Spa Pool Warning Signs	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> COS <input type="checkbox"/> M	
58	Spa Thermometer	<input type="checkbox"/> NVO <input type="checkbox"/> OUT <input checked="" type="checkbox"/> N/A <input type="checkbox"/> R <input type="checkbox"/> COS <input type="checkbox"/> M	
<b>VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS</b>			
<b>Item No</b>	<b>Remarks</b>		
1	Disinfectant Residual (ppm): 3.0		
2	pH: 7.6		
3	Cyanuric Acid (ppm): 0		
<b>Overall Inspection Comments:</b>			
Thursday, August 30, 2018 10:56 AM - JODI BIRD			
Pool okay to open - all previous violations corrected with the exception of the chair lift. See note below.			
<i>Chair lift needs new remote. Manager has ordered new remote.</i>			
<b>Received By</b>		<b>Title:</b>	<b>Date:</b>
JODI BIRD		EH Technician	8/30/2018