



**Yuba County Environmental Health**  
**915 8th Street Suite 123**  
**Marysville, CA 95901**  
**(530) 749-5450**

Record ID: PR0000874

**Inspection Report**

<b>Facility Name</b> WESTLAKE APARTMENTS		<b>Total Violations</b>		1	<b>Date:</b> 08/31/2018	<b>Total Time:</b> 30
<b>Facility Address</b> 1320 D ST		<b>Total Significant Violations</b>		0	<b>Start:</b> 10:15 am	<b>Finish:</b> 10:45 am
<b>City/State</b> MARYSVILLE, CA	<b>Zip Code</b> 95901	<b>Phone</b> (530) 673-1265	<b>Operator Name</b> SCOTT SWENSON		<b>Operator Phone</b> (916) 645-6333	
<b>Program:</b> 0860 - PUBLIC SWIMMING POOL-SPA PERMIT		<b>Service:</b> FOLLOW-UP		<b>Result:</b> FAILED TO MEET STANDARDS		

Fill in the designated compliance status (IN, OUT, N/O, N/A) for each numbered item

Fill in the appropriate box for COS and/or R

**In** = In compliance

**OUT** = Not In compliance

**N/O** = Not observed

**N/A** = Not applicable

**COS** = Corrected on-site during inspection

**R** = Repeat violation

0 "No Diving" Sign

**VIOLATIONS, OBSERVATIONS AND CORRECTIVE ACTIONS**

Item No	Remarks
	<p>Inadequate Record Keeping: Records for the pool facility are Inadequate. The facility shall Correct this violation immediately and must be submitted to Environmental Health in 7 days after the routine inspection date. Failure to provide an accurate, readable Daily Log, the facility shall be CLOSED for one week; (7) Days. After the one week closure of the pool facility a Daily log must be submitted to Environmental Health. Failure to do so will result in another one week CLOSURE of the pool facility and so on until adequate records are kept. The facility shall maintain a Daily log of the pool chemistry including;</p> <ol style="list-style-type: none"> <li>1. Disinfectant Residual</li> <li>2. pH</li> <li>3. Cyanuric Acid ( if applicable)</li> <li>4. Chemicals Added</li> <li>5. Filter Back Flushing</li> </ol> <p>CPC § 65523. Operation Records.</p> <p>(a) Except as provided in Health and Safety Code section 116048, the pool operator of every public pool open for use at a public pool site shall test the disinfectant residual and pH of the public pool water a minimum of once per day. The pool operator shall also test heated pools' water temperature a minimum of once per day. The pool operator may perform these daily tests using a properly calibrated automatic chemical monitoring and control system if approved by the enforcing agent and in accordance with the manufacturer's equipment specifications for calibration and directions for proper use. The pool operator shall maintain a written daily record of all test results, equipment readings and calibrations, and corrective action taken at the public pool site.</p>

**Overall Inspection Comments:**

*All signs properly posted today.*

*Daily readings are not being done by on-site manager. She said that she needs PSI to teach her how to do the testing. This violation must be corrected within 7 days.*

<b>Received By</b>	<b>Title:</b>	<b>Date:</b> 8/31/2018
<b>Inspector</b> JODI BIRD	<b>Title:</b> EH Technician	<b>Date:</b> 8/31/2018